

	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No.  S98A/0202	
1. Location	122a Carrigwood, Firhouse, Tallaght, Dublin 24.		
2. Development	Detached two storey house and driveway.		
3. Date of Application	02/04/98	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1.  2.	1.  2.
4. Submitted by	Name: D. J. Halpin, Address: 15 Carriglea Drive, Firhouse,		
5. Applicant	Name: Declan Murphy, Address: 122 Carrigwood, Firhouse, Dublin 24.		
6. Decision	O.C.M. No. 1026  Date 28/05/98	Effect RP REFUSE PERMISSION	
7. Grant	O.C.M. No.  Date	Effect RP REFUSE PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement	Compensation	Purchase Notice	
0	0	0	
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. .... Registrar	..... Date	..... Receipt No.	

**SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**



Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104

**PLANNING  
DEPARTMENT**  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

**NOTIFICATION OF DECISION TO REFUSE PERMISSION  
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

<b>Decision Order Number</b> 1026	<b>Date of Decision</b> 28/05/98
<b>Register Reference</b> S98A/0202	<b>Date</b> 2nd April 1998

**Applicant** Declan Murphy,  
**Development** Detached two storey house and driveway.  
**Location** 122a Carrigwood, Firhouse, Tallaght, Dublin 24.  
**Floor Area** Sq Metres  
**Time extension(s)** up to and including  
**Additional Information Requested/Received** /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a decision to **REFUSE PERMISSION** in respect of the above proposal.

for the (1) Reason on the attached Numbered Pages.

Signed on behalf of the South Dublin County Council

.....  
for SENIOR ADMINISTRATIVE OFFICER

28/05/98

D. J. Halpin,  
15 Carriglea Drive,  
Firhouse,  
Dublin 24.

SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



PLANNING  
DEPARTMENT  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104

REG REF. S98A/0202

**Reasons**

- 1 The Environmental Services Department of the Council has advised that the site of the proposed house is traversed by a 225mm diameter foul sewer. No development is permitted within 5m of this sewer. The proposed development would encroach on the reservation for the sewer and would be prejudicial to public health.

