


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S97B/0098	
1. Location	305C Belgard Heights, Belgard, Dublin 24.		
2. Development	2 storey extension at side with ancillary works.		
3. Date of Application	11/03/97	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: S. McCall & Associate Architects, Address: 116 Lower Drumcondra Road, Dublin 9.		
5. Applicant	Name: Laurence Murphy, Address: 305C Belgard Heights, Belgard, Dublin 24.		
6. Decision	O.C.M. No. 0848 Date 08/05/97	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 1211 Date 19/06/97	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement	Compensation	Purchase Notice	
0	0	0	
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. Registrar Date Receipt No.	

REG. REF. S97B/0098 **SOUTH DUBLIN COUNTY COUNCIL**
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



**PLANNING
DEPARTMENT**
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

S. McCall & Associate Architects,
116 Lower Drumcondra Road,
Dublin 9.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Final Grant Order Number 1211	Date of Final Grant 19/06/97
Decision Order Number 0848	Date of Decision 08/05/97
Register Reference S97B/0098	Date 11th March 1997

Applicant Laurence Murphy,

Development 2 storey extension at side with ancillary works.

Location 305C Belgard Heights, Belgard, Dublin 24.

Floor Area 0.000 Sq Metres

Time extension(s) up to and including


Additional Information Requested/Received /

A Permission has been granted for the development described above,
subject to the following (5) Conditions.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104


Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON:
To ensure that the development shall be in accordance with the permission, and that effective control be maintained.
 - 2 That the entire premises be used as a single dwelling unit.
REASON:
To prevent unauthorised development.
 - 3 That all external finishes harmonise in colour and texture with the existing premises.
REASON:
In the interest of visual amenity.
 - 4 Only clean uncontaminated surface water shall be discharged to the public surface water sewer. All foul waste shall be discharged to the public foul sewer.
REASON:
In the interest of public health.
 - 5 Where the proposed extension is within 5.0m of any public foul or surface water sewer or any public watermain then the foundations of the extension shall be taken down below the invert level of the deepest pipe.
REASON:
In the interest of the proper planning and development of the area and in the interest of public health.
-
- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1991 amended 1994.
 - (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
 - (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.

REG. REF. S97B/0098 SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

 June 1997
for SENIOR ADMINISTRATIVE OFFICER

**SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



**PLANNING
DEPARTMENT**
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

**NOTIFICATION OF DECISION TO GRANT PERMISSION
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

Decision Order Number 0848	Date of Decision 08/05/97
Register Reference S97B/0098	Date 11th March 1997

Applicant Laurence Murphy,
Development 2 storey extension at side with ancillary works.
Location 305C Belgard Heights, Belgard, Dublin 24.
Floor Area Sq Metres
Time extension(s) up to and including
Additional Information Requested/Received /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a **DECISION TO GRANT PERMISSION** in respect of the above proposal.

subject to the conditions (5) on the attached Numbered Pages.
Signed on behalf of the South Dublin County Council.

.....
for SENIOR ADMINISTRATIVE OFFICER

08/05/97

S. McCall & Associate Architects,
116 Lower Drumcondra Road,
Dublin 9.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104

REG REF. S97B/0098



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON:
To ensure that the development shall be in accordance with the permission, and that effective control be maintained.
- 2 That the entire premises be used as a single dwelling unit.
REASON:
To prevent unauthorised development.
- 3 That all external finishes harmonise in colour and texture with the existing premises.
REASON:
In the interest of visual amenity.
- 4 Only clean uncontaminated surface water shall be discharged to the public surface water sewer. All foul waste shall be discharged to the public foul sewer.
REASON:
In the interest of public health.
- 5 Where the proposed extension is within 5.0m of any public foul or surface water sewer or any public watermain then the foundations of the extension shall be taken down below the invert level of the deepest pipe.
REASON:
In the interest of the proper planning and development of the area and in the interest of public health.