


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)		Plan Register No. S97A/0675	
1. Location	Townlands of Kishoge and Kilmahuddrick.			
2. Development	To erect a new 38 kilovolt overhead electric line from a point in the townland of Kilmahuddrick to its proposed new Balgaddy 38kv substation in the townland of Kishoge.			
3. Date of Application	16/10/97	Date Further Particulars (a) Requested (b) Received		
3a. Type of Application	Permission	1.	1.	
		2.	2.	
4. Submitted by	Name: Electricity Supply Board Address: Leopardstown Road, Foxrock,			
5. Applicant	Name: Electricity Supply Board Address: Leopardstown Road, Foxrock, Dublin 18.			
6. Decision	O.C.M. No. 4264	Effect		
	Date 12/12/97	AP GRANT PERMISSION		
7. Grant	O.C.M. No. 0125	Effect		
	Date 21/01/98	AP GRANT PERMISSION		
8. Appeal Lodged				
9. Appeal Decision				
10. Material Contravention				
11. Enforcement	Compensation	Purchase Notice		
0	0	0		
12. Revocation or Amendment				
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal		
14. Registrar Date Receipt No.		

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
 Lár an Bhaile, Tamhlacht,
 Baile Átha Cliath 24.

Telefon: 01-462 0000
 Facs: 01-462 0104



**PLANNING
 DEPARTMENT**
 P.O. Box 4122,
 Town Centre, Tallaght,
 Dublin 24.

Telephone: 01-462 0000
 Fax: 01-462 0104

Electricity Supply Board
 Leopardstown Road,
 Foxrock,
 Dublin 18.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Final Grant Order Number 0125	Date of Final Grant 21/01/98
Decision Order Number 4264	Date of Decision 12/12/97
Register Reference S97A/0675	Date 16th October 1997

Applicant Electricity Supply Board

Development To erect a new 38 kilovolt overhead electric line from a point in the townland of Kilmahuddrick to its proposed new Balgaddy 38kV substation in the townland of Kishoge.

Location Townlands of Kishoge and Kilmahuddrick.

Floor Area 0.000 Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

A Permission has been granted for the development described above,
 subject to the following (5) conditions.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
 Lár an Bhaile, Tamhlacht,
 Baile Átha Cliath 24.

Telefon: 01-462 0000
 Facs: 01-462 0104

**PLANNING
 DEPARTMENT**
 P.O. Box 4122,
 Town Centre, Tallaght,
 Dublin 24.

Telephone: 01-462 0000
 Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON:
 To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 This permission shall be for a temporary period only until such time as the proposed 38KV line can be undergrounded in conjunction with the construction of the Outer Ring Road through this area. Applicant to consult within one month of grant of permission with the Development and Roads Department of this Planning Authority with a view to proposals being incorporated into the road design/ construction to accommodate this undergrounding at the expense of the applicant. Applicant to be responsible for decommissioning and removal of this temporary line at his own expense on completion of the undergrounding works.
REASON:
 In the interest of the proper planning and development of the area.

- 3 Details of location of proposed masts shall be submitted for agreement with the Planning Authority and Roads Department of South Dublin County Council. In this regard applicant shall take account of any road proposals in the vicinity.
REASON:
 In the interest of the proper planning and development of the area.


- 4 That the water supply and drainage arrangements, including the disposal of surface water, be in accordance with the requirements of the south Dublin County Council.
REASON:
 In order to comply with the Sanitary Services Acts, 1878 - 1964.

- 5 That the applicant secures the necessary wayleaves for the proposed line with affected landowners prior to construction commencing.
REASON:
 In the interest of the proper planning and development of the area.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1991 amended 1994.
- (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

  January 1998
for SENIOR ADMINISTRATIVE OFFICER