


| | | |
|-----------------------------|---|--|
| | South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1) | Plan Register No. S97A/0340 |
| 1. Location | Oldbawn Community School, Oldbawn, Tallaght, Dublin 24. | |
| 2. Development | Permission for new play area, site entrance gates, and boundary walls and fencing to site extension for Oldbawn Community School. | |
| 3. Date of Application | 30/05/97 | Date Further Particulars (a) Requested (b) Received |
| 3a. Type of Application | Permission | 1. 2. |
| 4. Submitted by | Name: J. Stack Associates, Address: Architects, 84 South Park, | |
| 5. Applicant | Name: The Department of Education, Address: Marlborough Street, Dublin 1. | |
| 6. Decision | O.C.M. No. 1462 Date 23/07/97 | Effect AP GRANT PERMISSION |
| 7. Grant | O.C.M. No. 1810 Date 09/09/97 | Effect AP GRANT PERMISSION |
| 8. Appeal Lodged | | |
| 9. Appeal Decision | | |
| 10. Material Contravention | | |
| 11. Enforcement | Compensation | Purchase Notice |
| 0 | 0 | 0 |
| 12. Revocation or Amendment | | |
| 13. E.I.S. Requested | E.I.S. Received | E.I.S. Appeal |
| 14. Registrar | Date | Receipt No. |

REG REF. S97A/0340 SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

J. Stack Associates,
Architects,
84 South Park,
Foxrock,
Dublin 18.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

| | |
|-------------------------------|------------------------------|
| Final Grant Order Number 1810 | Date of Final Grant 09/09/97 |
| Decision Order Number 1462 | Date of Decision 23/07/97 |
| Register Reference S97A/0340 | Date 30th May 1997 |

Applicant The Department of Education,

Development Permission for new play area, site entrance gates, and boundary walls and fencing to site extension for Oldbawn Community School.

Location Oldbawn Community School, Oldbawn, Tallaght, Dublin 24.

Floor Area 8518.000 Sq Metres

Time extension(s) up to and including


Additional Information Requested/Received /

A Permission has been granted for the development described above,
subject to the following (5) conditions.

REG. REF. S97A/0340 SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104


Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON:
To ensure that the development shall be in accordance with the permission and that effective control be maintained.
- 2 The row of poplars on the existing southern boundary shall be retained in full.
REASON:
In the interest of visual amenity.
- 3 The railings in the vicinity of the tennis courts shall be altered to prevent tennis balls passing through the bars.
REASON:
In the interest of the proper planning and development of the area.
- 4 The piers on either side of the entrance shall be set back at least 0.5m from the edge of the carriageway.
REASON:
To allow safe vehicular access in the interest of traffic safety.
- 5 All surface water shall be discharged to the stream to the south. Wing walls, head wall and apron area shall be constructed to the standards of South Dublin County Council Environmental Services Department.
REASON:
In the interest of public health.

REG REF. S97A/0340 SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1991 amended 1994.
- (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

.....*Annette Daly*.....September 1997
for SENIOR ADMINISTRATIVE OFFICER

Telefon: 01-462 0000
Facs: 01-462 0104

Telephone: 01-462 0000
Fax: 01-462 0104

| | |
|------------------------------|---------------------------|
| Decision Order Number 1462 | Date of Decision 23/07/97 |
| Register Reference S97A/0340 | Date 30th May 1997 |

..... 23/07/97
for SENIOR ADMINISTRATIVE OFFICER

J. Stack Associates,
Architects,
84 South Park,
Foxrock,
Dublin 18.


SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000

Facs: 01-462 0104

REG REF. S97A/0340



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000

Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
REASON:
To ensure that the development shall be in accordance with the permission and that effective control be maintained.
- 2 The row of poplars on the existing southern boundary shall be retained in full.
REASON:
In the interest of visual amenity.
- 3 The railings in the vicinity of the tennis courts shall be altered to prevent tennis balls passing through the bars.
REASON:
In the interest of the proper planning and development of the area.
- 4 The piers on either side of the entrance shall be set back at least 0.5m from the edge of the carriageway.
REASON:
To allow safe vehicular access in the interest of traffic safety.
- 5 All surface water shall be discharged to the stream to the south. Wing walls, head wall and apron area shall be constructed to the standards of South Dublin County Council Environmental Services Department.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104

REG. REF. S97A/0340



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

REASON:

In the interest of public health.