


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S97A/0017	
1. Location	Cookstown Townland, Co. Dublin.		
2. Development	Erect 4 structures in a section of the existing Belgard - Tallaght and Carrickmines - Cookstown - Inchicore 110kv lines to raise the height of the overhead wires to accommodate the Cookstown Road and light Rail Transport developments. 4 new lattice steel towers of maximum height 32.1m and maximum base area circa 41 square metres supporting the existing line which consists of 6 overhead steel reinforced aluminium conductors. The average distance between structures will be 120 metres.		
3. Date of Application	20/01/97	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Peter Hore, Address: ESBI Engineering Ltd., Stephen's Court, 18/21 St. Stephen's Green,		
5. Applicant	Name: Electricity Supply Board, Address: 27 Lower Fitzwilliam Street, Dublin 2.		
6. Decision	O.C.M. No. 0513 Date 18/03/97	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 0872 Date 01/05/97	Effect	

8.	Appeal Notified		
9.	Appeal Decision		
10.	Material Contravention		
11.	Enforcement 0	Compensation 0	Purchase Notice 0
12.	Revocation or Amendment		
13.	E.I.S. Requested	E.I.S. Received	E.I.S. Appeal
14. Registrar Date Receipt No.

REG. REF. S97A/0017 SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Peter Hore,
ESBI Engineering Ltd.,
Stephen's Court,
18/21 St. Stephen's Green,
Dublin 2.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Final Grant Order Number 0872	Date of Final Grant 01/05/97
Decision Order Number 0513	Date of Decision 18/03/97
Register Reference S97A/0017	Date 20th January 1997

Applicant Electricity Supply Board,

Development Erect 4 structures in a section of the existing Belgard - Tallaght and Carrickmines - Cookstown - Inchicore 110kv lines to raise the height of the overhead wires to accommodate the Cookstown Road and light Rail Transport developments. 4 new lattice steel towers of maximum height 32.1m and maximum base area circa 41 square metres supporting the existing line which consists of 6 overhead steel reinforced aluminium conductors. The average distance between structures will be 120 metres.

Location Cookstown Townland, Co. Dublin.

Floor Area 0.000 Sq Metres


Time extension(s) up to and including

Additional Information Requested/Received /

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



**PLANNING
DEPARTMENT**
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

A Permission has been granted for the development described above,
subject to the following (2) conditions.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
 Lár an Bhaile, Tamhlacht,
 Baile Átha Cliath 24.

Telefon: 01-462 0000
 Facs: 01-462 0104



**PLANNING
 DEPARTMENT**
 P.O. Box 4122,
 Town Centre, Tallaght,
 Dublin 24.

Telephone: 01-462 0000
 Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application as amended by unsolicited additional information received by the Planning Authority on 11/3/97, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 The final position of proposed tower 27A/98A shall be agreed on site with a representative from the Roads Design Department of South Dublin County Council.

REASON:

In the interest of traffic safety and the proper planning and development of the area.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1991 amended 1994.
- (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

 26 May 1997
 for SENIOR ADMINISTRATIVE OFFICER