

COMHAIRLE CHONTAE ÁTHA CLIATH

S

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER	REGISTER REFERENCE YA. 238
1. LOCATION	2/3 Greenhills Road, Tallaght	
2. PROPOSAL	Four light industrial warehouse units	
3. TYPE & DATE OF APPLICATION	TYPE	Date Received
	P.	28.2.83
	Date Further Particulars	
	(a) Requested	(b) Received
	1. 13th April, 1983 24th June, 1983	1. 25th April, 1983
	2.	2.
4. SUBMITTED BY	Name Mr. P. Murtagh, Address 31 St. Killians Avenue, Walkinstown, Dublin 12	
5. APPLICANT	Name Mr. A. Molloy, Address 72 Orwell Park, Templeogue, Dublin 12	
6. DECISION	O.C.M. No.	Notified
	Date	Effect
7. GRANT	O.C.M. No.	Notified
	Date	Effect
8. APPEAL	Notified	Decision
	Type	Effect
9. APPLICATION SECTION 26 (3)	Date of application	Decision
		Effect
10. COMPENSATION	Ref. in Compensation Register	
11. ENFORCEMENT	Ref. in Enforcement Register	
12. PURCHASE NOTICE		
13. REVOCATION or AMENDMENT		
14.		
15.		

Prepared by

Checked by

Copy issued by Registrar.

Date

Co. Accts. Receipt No

YA.338

24th June, 1983.

P. Murtagh,
31, St. Killian's Ave.,
Walkinstown,
Dublin 12.

Re: Proposed block of four light industrial warehouse units at 2-3,
Greenhills Road, Ballymount Road Upper for A. Mollove

Dear Sir,

With reference to your planning application received here on 28/2/'83, additional information received 25/4/'83 in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts, 1963-1982, the following additional information must be submitted in quadruplicate;

1. a) In respect of the foul drainage system proposed, details of pipe sizes and gradients, pumping station and system it is proposed to connect to including location of CONNECTION.
- b) If the applicants propose to connect to a private foul drainage system in the adjoining lands, the following details are required:-
 - i) Clarification that the system would be capable of accommodating the flow it was designed to carry plus the foul discharge from this site.
 - ii) Evidence from the owners of the adjoining lands that any arrangement to connect to a private sewer is permitted.
2. In respect of surface water drainage, details of the design calculations treatment of outfall, and sections indicating pipe sizes and gradient to the point of outfall to the stream are required.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,



for Principal Officer

YA 338

13th April, 1983.

P. Murtagh,
31 St. Killian's Avenue,
Walkinstown,
Dublin 12.

Re: Proposed block of four light industrial warehouses
units at 2-3 Greenhills Road, Ballymount Road Upper,
for A. Molloy.


Dear Sir,

With reference to your planning application received here on 28th February, 1983, in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts, 1963-1982, the following additional information must be submitted in quadruplicate:-

1. Applicant to clarify how it is proposed to comply with the requirements of the Housing Act 1969 in relation to House nos. 2 and 3, Greenhills Road, also the applicant is to clarify the present and proposed use of each of these cottages. Applicant to produce the necessary permission under the Housing Act.
2. Applicant to clarify that he has sufficient interest in each of the cottage plots to enable him to carry out the proposed development or alternatively submit evidence of the consent of the owners in each case to the making of the application.
3. Applicant to clarify how it is proposed to supply water and drainage arrangements to serve the proposed development on a suitably sealed plan.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,


For Principal Officer.