


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S96A/0446	
1. Location	Townlands of Palmerstown Upper, Irishtown and Woodfarm.		
2. Development	Alter the existing 38kv Kilovolt overhead electric line.		
3. Date of Application	16/08/96	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Electricity Supply Board, Address: Leopardstown Road, Foxrock,		
5. Applicant	Name: Electricity Supply Board, Address: c/o T.J. Murray, Regional Manager, Dublin Region, Leopardstown Road, Foxrock, Dublin 18.		
6. Decision	O.C.M. No. 2013 Date 14/10/96	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 2307 Date 03/12/96	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement	Compensation	Purchase Notice	
0	0	0	
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. Registrar Date Receipt No.	

SOUTH DUBLIN COUNTY COUNCIL

COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104

PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

Electricity Supply Board,
Leopardstown Road,
Foxrock,
Dublin 18.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Final Grant Order Number 2307	Date of Final Grant 03/12/96
Decision Order Number 2013	Date of Decision 14/10/96
Register Reference S96A/0446	Date 16th August 1996

Applicant Electricity Supply Board,

Development Alter the existing 38kV Kilovolt overhead electric line.

Location Townlands of Palmerstown Upper, Irishtown and Woodfarm.

Floor Area 0.000 Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

A Permission has been granted for the development described above,
subject to the following (2) Conditions.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104

**PLANNING
DEPARTMENT**
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 The cable shall be placed underground over the full length of the proposed route shown coloured red on the drawing submitted with the planning application. Full details of required support structures at either end of the undergrounded cable shall be submitted to and be agreed in writing with the Planning Authority prior to the commencement of development.


REASON:

In the interests of visual amenity generally but with particular reference to the proximity to the proposed development to the Liffey Valley Special Amenity Area and compliance with the policies regarding electricity cables as set out in the Dublin County Development Plan 1993.

All buildings must now be designed and constructed in accordance with the new Building Regulations. The Regulations also provide that a Commencement Notice must be submitted to the Building Control Authority in respect of all buildings other than exempted development for the purposes of the Local Government (Planning and Development) Acts, 1963 - 1993, not less than seven days and not more than twenty-one days before development commences. A copy of the form of commencement notice is attached.

In addition, a Fire Certificate must be obtained from the Building Control Authority in respect of the erection, alteration or change of use of all buildings other than dwelling houses.


Signed on behalf of South Dublin County Council.

 3rd December 1996
for SENIOR ADMINISTRATIVE OFFICER

**SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000
Facs: 01-462 0104



**PLANNING
DEPARTMENT**
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000
Fax: 01-462 0104

**NOTIFICATION OF DECISION TO GRANT PERMISSION
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

Decision Order Number 2013	Date of Decision 14/10/96
Register Reference S96A/0446	Date 16th August 1996

Applicant Electricity Supply Board,
Development Alter the existing 38kv Kilovolt overhead electric line.
Location Townlands of Palmerstown Upper, Irishtown and Woodfarm.
Floor Area Sq Metres
Time extension(s) up to and including
Additional Information Requested/Received /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a decision to **GRANT PERMISSION** in respect of the above proposal.


subject to the conditions (2) on the attached Numbered Pages.
signed on behalf of the South Dublin county Council.

.....
for SENIOR ADMINISTRATIVE OFFICER

14/10/96

Electricity Supply Board,
Leopardstown Road,
Foxrock,
Dublin 18.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-462 0000

Facs: 01-462 0104

REG REF. S96A/0446

PLANNING
DEPARTMENT

P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-462 0000

Fax: 01-462 0104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 The cable shall be placed underground over the full length of the proposed route shown coloured red on the drawing submitted with the planning application. Full details of required support structures at either end of the undergrounded cable shall be submitted to and be agreed in writing with the Planning Authority prior to the commencement of development.

REASON:

In the interests of visual amenity generally but with particular reference to the proximity to the proposed development to the Liffey Valley Special Amenity Area and compliance with the policies regarding electricity cables as set out in the Dublin County Development Plan 1993.