


C

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Halla an Chontae,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



**PLANNING
DEPARTMENT**
County Hall,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1999
AND PLANNING AND DEVELOPMENT ACT 2000

Decision Order Number 2946	Date of Decision 18/09/2001
Register Reference S01A/0480	Date: 20/07/01

Applicant David K'Eogh
Development New timber frame and door to K'Eogh family vault (a
 protected structure).

Location St. Finian's, Newcastle-Lyons, Church of Ireland, Newcastle,
 Co. Dublin.

App. Type Permission

Dear Sir/Madam,

With reference to your planning application, received on 20/07/01 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning & Development) Acts 1963-1999 and the Planning and Development Act 2000, the following ADDITIONAL INFORMATION must be submitted in quadruplicate:


- 1 the applicant shall note that a site location map as required by Article 18 of the Local Government (Planning and Development) Regulations, 1994, has not been submitted. The applicant is therefore requested to submit a revised site location map which clearly identifies the site in the context of the surrounding area.
- 2 The applicant shall note that Article 14 of the Government (Planning and Development) [no.2] Regulations, 1999, states that "where development would consist of or comprise the carrying out of works to a protected structure or a proposed protected structure, a planning application shall... be accompanied by such plans and other particulars as are necessary to show how the development would affect the character of the Structure". In this regard, Duchas, The Heritage Service require the further submission to the Planning Authority, of the following:

David K'Eogh, Architect,
74 Moyne Road,
Ranelagh,
Dublin 6.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Halla an Chontae,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



PLANNING
DEPARTMENT
County Hall,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

REG REF. S01A/0480

- (a) survey plans of the existing doorway showing if any door, over-door light or grille exists
- (b) photographs of the external elevations and interior of the doorway
- (c) Should a door, over-door light or grille remain, they should be repaired as necessary. Materials should be indicated on the drawings.

If the applicant can demonstrate that any existing door/over-door light or grille is beyond repair, the details of the existing should be taken and used as the basis for the replacement work. The survey drawing should note the presence of socket holes for any existing or previous iron grille, and any proposed grille should follow this pattern.

Signed on behalf of South Dublin County Council

.....
for Senior Administrative Officer

18/09/01