

	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1999 and Planning & Development Act 2000 Planning Register (Part 1)	Plan Register No.  S00A/0830	
1. Location	Grange Castle Business Park, Clondalkin, Dublin 22.		
2. Development	Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakilly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.		
3. Date of Application	30/11/00	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Mr. Mark Halpin, Address: ESB International, 18-21 St. Stephens Green,		
5. Applicant	Name: Electricity Supply Board, Address: 27 Lwr. Fitzwilliam Street, Dublin 2.		
6. Decision	O.C.M. No. 0199  Date 26/01/2001	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 0518  Date 08/03/2001	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement		Compensation	Purchase Notice
12. Revocation or Amendment			
13. E.I.S. Requested		E.I.S. Received	E.I.S. Appeal

14.

Registrar


Date

Receipt No.

**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Halla an Chontae,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
County Hall,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

NOTIFICATION OF DECISION TO GRANT PERMISSION  
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 0199	Date of Decision 26/01/2001
Register Reference S00A/0830	Date: 30/11/00

**Applicant** Electricity Supply Board,

**Development** Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakailly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.

**Location** Grange Castle Business Park, Clondalkin, Dublin 22.

**Floor Area** Sq Metres

**Time extension(s) up to and including**

**Additional Information Requested/Received** /

**Clarification of Additional Information Requested/Received** /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a DECISION TO GRANT PERMISSION in respect of the above proposal.

Subject to the conditions ( 3 ) on the attached Numbered Pages.  
Signed on behalf of the South Dublin County Council.


..... *MY* ..... 26/01/01  
for SENIOR ADMINISTRATIVE OFFICER

Mr. Mark Halpin,  
ESB International,  
18-21 St. Stephens Green,  
Dublin 2.

SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Halla an Chontae,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



PLANNING  
DEPARTMENT  
County Hall,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

REG REF. S00A/0830

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 That before development commences, the applicant shall submit for agreement by the Planning Authority details of proposed landscaping and boundary treatment of the proposed compound.

REASON:

In the interest of visual amenity and to minimise the visual intrusion of the compound.

- 3 Before development commences, the applicant shall submit for agreement by the Planning Authority accurately scaled drawings of the proposed steel towers.

REASON:

In the interest of the proper planning and development of the area.



	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1999 and Planning & Development Act 2000 Planning Register (Part 1)	Plan Register No.  S00A/0830
1. Location	Grange Castle Business Park, Clondalkin, Dublin 22.	
2. Development	Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakailly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.	
3. Date of Application	30/11/00	Date Further Particulars (a) Requested (b) Received
3a. Type of Application	Permission	1. 2. 1. 2.
4. Submitted by	Name: Mr. Mark Halpin, Address: ESB International, 18-21 St. Stephens Green,	
5. Applicant	Name: Electricity Supply Board, Address: 27 Lwr. Fitzwilliam Street, Dublin 2.	
6. Decision	O.C.M. No. 0199  Date 26/01/2001	Effect AP GRANT PERMISSION
7. Grant	O.C.M. No. 0518  Date 08/03/2001	Effect AP GRANT PERMISSION
8. Appeal Lodged		
9. Appeal Decision		
10. Material Contravention		
11. Enforcement	Compensation	Purchase Notice
12. Revocation or Amendment		
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal


14.

Registrax

Date

Receipt No.

**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**



Halla an Chontae  
Lár an Bhaile, Tamhlacht  
Baile Átha Cliath 24

Telefon: 01-414 9230  
Facs: 01-414 9104

**PLANNING DEPARTMENT**  
**Applications/Registry/Appeals**

County Hall  
Town Centre, Tallaght  
Dublin 24

Telephone: 01-414 9230  
Fax: 01-414 9104

Mr. Mark Halpin,  
ESB International,  
18-21 St. Stephens Green,  
Dublin 2.

**NOTIFICATION OF GRANT OF Permission**

**LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

Final Grant Order Number 0518	Date of Final Grant 08/03/2001
Decision Order Number 0199	Date of Decision 26/01/2001
Register Reference S00A/0830	Date 30/11/00

**Applicant** Electricity Supply Board,

**Development** Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakilly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.

**Location** Grange Castle Business Park, Clondalkin, Dublin 22.

**Floor Area** 0.00 Sq Metres

**Time extension(s) up to and including**

**Additional Information Requested/Received** /

A Permission has been granted for the development described above,  
subject to the following (3) Conditions.



**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**



Halla an Chontae  
 Lár an Bhaile, Tamhlacht  
 Baile Átha Cliath 24

Telefon: 01-414 9230  
 Facs: 01-414 9104

**PLANNING DEPARTMENT**  
**Applications/Registry/Appeals**  
 County Hall  
 Town Centre, Tallaght  
 Dublin 24

Telephone: 01-414 9230  
 Fax: 01-414 9104

**Conditions and Reasons**

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

**REASON:**

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 That before development commences, the applicant shall submit for agreement by the Planning Authority details of proposed landscaping and boundary treatment of the proposed compound.

**REASON:**

In the interest of visual amenity and to minimise the visual intrusion of the compound.

- 3 Before development commences, the applicant shall submit for agreement by the Planning Authority accurately scaled drawings of the proposed steel towers.

**REASON:**

In the interest of the proper planning and development of the area.

- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council,

  
 .....12/03/01  
 for SENIOR ADMINISTRATIVE OFFICER



	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1999 and Planning & Development Act 2000 Planning Register (Part 1)	Plan Register No.  S00A/0830	
1. Location	Grange Castle Business Park, Clondalkin, Dublin 22.		
2. Development	Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakailly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.		
3. Date of Application	30/11/00	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Mr. Mark Halpin, Address: ESB International, 18-21 St. Stephens Green,		
5. Applicant	Name: Electricity Supply Board, Address: 27 Lwr. Fitzwilliam Street, Dublin 2.		
6. Decision	O.C.M. No. 0199  Date 26/01/2001	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 0518  Date 08/03/2001	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement		Compensation	Purchase Notice
12. Revocation or Amendment			
13. E.I.S. Requested		E.I.S. Received	E.I.S. Appeal

**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Halla an Chontae,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
County Hall,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

**NOTIFICATION OF DECISION TO GRANT PERMISSION**  
**LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

Decision Order Number 0199	Date of Decision 26/01/2001
Register Reference S00A/0830	Date: 30/11/00

**Applicant** Electricity Supply Board,

**Development** Build a new 110kv lines/cable interface compound and a line diversion of the existing Inchicore-Maynooth 110kv line in the townland of Grange. The proposed 110kv compound and overhead line will be erected over, or in the vicinity of the townlands of Ballymakilly and Grange. The line will consist of 6 no. overhead wires supported on lattice steel structures of average height of 21 metres, with average base area of 7 metres sq.

**Location** Grange Castle Business Park, Clondalkin, Dublin 22.

**Floor Area** Sq Metres

**Time extension(s)** up to and including

**Additional Information Requested/Received** /

**Clarification of Additional Information Requested/Received** /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a DECISION TO GRANT PERMISSION in respect of the above proposal.

Subject to the conditions ( 3 ) on the attached Numbered Pages.  
Signed on behalf of the South Dublin County Council.


..... *m7* ..... 26/01/01  
for SENIOR ADMINISTRATIVE OFFICER

Mr. Mark Halpin,  
ESB International,  
18-21 St. Stephens Green,  
Dublin 2.

**SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Halla an Chontae,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
County Hall,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

REG REF. S00A/0830

**Conditions and Reasons**

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.  
REASON:  
To ensure that the development shall be in accordance with the permission and that effective control be maintained.
- 2 That before development commences, the applicant shall submit for agreement by the Planning Authority details of proposed landscaping and boundary treatment of the proposed compound.  
REASON:  
In the interest of visual amenity and to minimise the visual intrusion of the compound.
- 3 Before development commences, the applicant shall submit for agreement by the Planning Authority accurately scaled drawings of the proposed steel towers.  
REASON:  
In the interest of the proper planning and development of the area.