

	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S00A/0536	
1. Location	Kilmahuddrick, Co. Dublin.		
2. Development	To build a new 110kV L/C compound and a line diversion of the existing Inchicore - Maynooth 110kV line in the townland of Kilmahuddrick. The proposed 110kV compound and overhead line will be erected over, or in the vicinity of the townlands of Kilmahuddrick, Kishoge and Grange. The line will consist of 6 No. overhead wires supported on lattice steel structures, of average height of 15 metres, with average base area of 5 metres square.		
3. Date of Application	03/08/00	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Mr. M. Halpin Address: ESB International, 18-21 St. Stephens Green,		
5. Applicant	Name: Electricity Supply Board Address: 27. Lr. Fitzwilliam Street, Dublin 2.		
6. Decision	O.C.M. No. 2180 Date 26/09/2000	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. Date	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement		Compensation	Purchase Notice
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	

14.

Registrar


Date

Receipt No.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Halla an Chontae,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



**PLANNING
DEPARTMENT**
County Hall,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

NOTIFICATION OF DECISION TO GRANT PERMISSION
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 2180	Date of Decision 26/09/2000
Register Reference S00A/0536	Date: 03/08/00

Applicant Electricity Supply Board

Development To build a new 110kV L/C compound and a line diversion of the existing Inchicore - Maynooth 110kV line in the townland of Kilmahuddrick. The proposed 110kV compound and overhead line will be erected over, or in the vicinity of the townlands of Kilmahuddrick, Kishoge and Grange. The line will consist of 6 No. overhead wires supported on lattice steel structures, of average height of 15 metres, with average base area of 5 metres square.

Location Kilmahuddrick, Co. Dublin.

Floor Area Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

Clarification of Additional Information Requested/Received /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a **DECISION TO GRANT PERMISSION** in respect of the above proposal.

Subject to the conditions (2) on the attached Numbered Pages.
Signed on behalf of the South Dublin County Council.

 26/09/00
for SENIOR ADMINISTRATIVE OFFICER

Mr. M. Halpin
ESB International,
18-21 St. Stephens Green,
Dublin 2.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Halla an Chontae,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



**PLANNING
DEPARTMENT**
County Hall,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

REG REF. S00A/0536

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 That before development commences, the applicant shall submit for agreement by the Planning Authority details of proposed landscaping and boundary treatment of the proposed compound.

REASON:

In the interest of visual amenity and to minimise the visual intrusion of the compound.