


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S00A/0171	
1. Location	Shinko Microelectronics, Greenhills Center, Greenhills Road Tallaght, Dublin 24		
2. Development	To upgrade existing nitrogen tank from 12 metres high x 2.35 metres diameter to 12 metres high x 2.85 metres diameter at their premises at Greenhills Centre, Greenhills Road, Dublin 24.		
3. Date of Application	16/03/00	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Michael Keogh Address: Project Management, Kilakee House,		
5. Applicant	Name: Mr. Jimmy Carthy Address: Shinko Microelectronics, Greenhills Center, Greenhills RoadTallaght, Dublin 24		
6. Decision	O.C.M. No. 1039 Date 12/05/2000	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. 1369 Date 22/06/2000	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement		Compensation	Purchase Notice
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. Registrar Date Receipt No.	

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Halla an Chontae
Lár an Bhaile, Tamhlacht
Baile Átha Cliath 24

Telefon: 01-414 9230
Facs: 01-414 9104

PLANNING DEPARTMENT
Applications/Registry/Appeals

County Hall
Town Centre, Tallaght
Dublin 24

Telephone: 01-414 9230
Fax: 01-414 9104

Michael Keogh
Project Management,
Kilakee House,
Belgard Square,
Dublin 24.

NOTIFICATION OF GRANT OF Permission

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Final Grant Order Number 1369	Date of Final Grant 22/06/2000
Decision Order Number 1039	Date of Decision 12/05/2000
Register Reference S00A/0171	Date 16/03/00

Applicant Mr. Jimmy Carthy

Development To upgrade existing nitrogen tank from 12 metres high x 2.35 metres diameter to 12 metres high x 2.85 metres diameter at their premises at Greenhills Centre, Greenhills Road, Dublin 24.

Location Shinko Microelectronics, Greenhills Center, Greenhills Road Tallaght, Dublin 24


Floor Area 5580.00 Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

A Permission has been granted for the development described above,
subject to the following (10) Conditions.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Halla an Chontae
 Lár an Bhaile, Tamhlacht
 Baile Átha Cliath 24

Telefon: 01-414 9230
 Facs: 01-414 9104

PLANNING DEPARTMENT
Applications/Registry/Appeals
 County Hall
 Town Centre, Tallaght
 Dublin 24

Telephone: 01-414 9230
 Fax: 01-414 9104

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.
 REASON:
 To ensure that the development shall be in accordance with the permission and that effective control be maintained.
- 2 During the construction phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. There must be compliance with British Standard B.S. 5228 Noise Control on Construction and Open Sites.
 REASON:
 In the interests of public health.
- 3 Smoke, grit, dust, ash, acid spray or liquid droplets shall not be emitted from the premises in such a manner or quantity as to give rise to a nuisance to persons in the neighbourhood.
 REASON:
 In the interests of public health.
- 4 The developer shall ensure that the lighting system is designed to minimise potential pollution from glare and spillage.
 REASON:
 In the interest of public health.
- 5 The applicant shall ensure the structural safety of the existing tanks during the construction of the new tank.
 REASON:
 In the interests of public health and safety.
- 6 The applicant shall ensure that procedures are put in place to deal with any spillages. The tank shall be designed to minimise spillage, release of vapours and the effect of fire.
 REASON:
 In the interests of public health and safety.
- 7 All parts of the piping system should be made from materials compatible with the liquid being handled.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Halla an Chontae
Lár an Bhaile, Tamhlacht
Baile Átha Cliath 24

Telefon: 01-414 9230
Facs: 01-414 9104

PLANNING DEPARTMENT
Applications/Registry/Appeals
County Hall
Town Centre, Tallaght
Dublin 24

Telephone: 01-414 9230
Fax: 01-414 9104

REASON:

In the interests of public health and safety.

- 8 Valves should exist for isolating the supply after use, during maintenance and in the event of an emergency.

REASON:

In the interests of public health and safety.

- 9 The applicant shall have suitable regard to the British Compressed Gases Association Code of Practice for Bulk Argon and Nitrogen storage at Users Premises CP21.

REASON:

In the interests of public health and safety.

- 10 The applicant shall ascertain prior to commencement of development and comply with the requirements of the Chief Fire Officer and the Health and Safety Authority.

REASON:

In the interest of public health and safety.


- (1) All buildings must be designed and constructed in accordance with the Building Regulations 1997.
- (2) Building Control Regulations require a Commencement Notice. A copy of the Commencement Notice is attached.
- (3) A Fire Safety Certificate must be obtained from the Building Control Authority, where applicable.
- (4) Free Standing Walls must be designed and constructed in accordance with IS 325: Code of Practice for use of Masonry Part 1 : Structural use of unreinforced Masonry. The Owner must also ensure that the construction of all walls is supervised by a competent person.

Signed on behalf of South Dublin County Council.

.....23/06/00
for SENIOR ADMINISTRATIVE OFFICER

	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S00A/0171	
1. Location	Shinko Microelectronics, Greenhills Center, Greenhills Road Tallaght, Dublin 24		
2. Development	To upgrade existing nitrogen tank from 12 metres high x 2.35 metres diameter to 12 metres high x 2.85 metres diameter at their premises at Greenhills Centre, Greenhills Road, Dublin 24.		
3. Date of Application	16/03/00	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 2.	1. 2.
4. Submitted by	Name: Michael Keogh Address: Project Management, Kilakee House,		
5. Applicant	Name: Mr. Jimmy Carthy Address: Shinko Microelectronics, Greenhills Center, Greenhills RoadTallaght, Dublin 24		
6. Decision	O.C.M. No. 1039 Date 12/05/2000	Effect AP GRANT PERMISSION	
7. Grant	O.C.M. No. Date	Effect AP GRANT PERMISSION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement		Compensation	Purchase Notice
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. Registrar	Date	Receipt No.	

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104

PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

NOTIFICATION OF DECISION TO GRANT PERMISSION
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 1039	Date of Decision 12/05/2000
Register Reference S00A/0171	Date: 16/03/00

Applicant Mr. Jimmy Carthy

Development To upgrade existing nitrogen tank from 12 metres high x 2.35 metres diameter to 12 metres high x 2.85 metres diameter at their premises at Greenhills Centre, Greenhills Road, Dublin 24.

Location Shinko Microelectronics, Greenhills Center, Greenhills Road Tallaght, Dublin 24

Floor Area Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

Clarification of Additional Information Requested/Received /


In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a DECISION TO GRANT PERMISSION in respect of the above proposal.

Subject to the conditions (10) on the attached Numbered Pages.
Signed on behalf of the South Dublin County Council.

..... 12/05/00
for SENIOR ADMINISTRATIVE OFFICER

Michael Keogh
Project Management,
Kilakee House,
Belgard Square,
Dublin 24.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104

PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

REG REF. S00A/0171

Conditions and Reasons

- 1 The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.

REASON:

To ensure that the development shall be in accordance with the permission and that effective control be maintained.

- 2 During the construction phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances. There must be compliance with British Standard B.S. 5228 Noise Control on Construction and Open Sites.

REASON:

In the interests of public health.

- 3 Smoke, grit, dust, ash, acid spray or liquid droplets shall not be emitted from the premises in such a manner or quantity as to give rise to a nuisance to persons in the neighbourhood.

REASON:

In the interests of public health.

- 4 The developer shall ensure that the lighting system is designed to minimise potential pollution from glare and spillage.

REASON:

In the interest of public health.


- 5 The applicant shall ensure the structural safety of the existing tanks during the construction of the new tank.

REASON:

In the interests of public health and safety.

- 6 The applicant shall ensure that procedures are put in place to deal with any spillages. The tank shall be designed to

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104

PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

REG. REF. S00A/0171

minimise spillage, release of vapours and the effect of
fire.

REASON:

In the interests of public health and safety.

- 7 All parts of the piping system should be made from materials
compatible with the liquid being handled.

REASON:

In the interests of public health and safety.

- 8 Valves should exist for isolating the supply after use,
during maintenance and in the event of an emergency.

REASON:

In the interests of public health and safety.

- 9 The applicant shall have suitable regard to the British
Compressed Gases Association Code of Practice for Bulk Argon
and Nitrogen storage at Users Premises CP21.

REASON:

In the interests of public health and safety.

- 10 The applicant shall ascertain prior to commencement of
development and comply with the requirements of the Chief
Fire Officer and the Health and Safety Authority.

REASON:

In the interest of public health and safety.