COMHAIRLE CHONTAE ATHA CLIATH

File Reference P.C. 17640		LOCAI	L GOVERNMENT (PI DEVELOPMENT) A PLANNING REG		IG AND	REGISTER REFERENCE M. 1870
1. LOCATION		Gortlum, Brittas, Co. Dublin.				
2. PROPOSAL		\$	Septic tank.			
3. TYPE & DATE OF APPLICATI	ON	P. 18th July, 1977			Date Further equested 5/9/77	er Particulars (b) Received 1
4. SUBMITTED BY	ŕ	Name Mrs. Margaret Proctor, Address Gortlum, Brittas, Co. Dublin.				
5. APPLICANT		Name Mrs. Margaret Proctor, Address Gortlum, Brittas, Co. Dublin.				
6. DECISION		O.C.M. No Date	>.		Notified Effect	
7. GRANT		O.C.M. No. Date			Notified Effect	
8. APPEAL		Notified Type			Decision Effect	
9. APPLICATION SECTION 26 (3)		Date of application			Decision Effect	
10. COMPENSATION		Ref. in Compensation Register				
11. ENFORCEMENT		Ref. in Enforcement Register				
12. PURCHASE NOTICE						
13. REVOCATION or AMENDMENT						=
14.						
115.						
16.		×				
Prepared by		Copy issued by				Registrar
Checked by						
Grid Ref. O.S. Sheet			Co. Accts. Receipt	: No		<u>-10)</u>

p [3312/17) 15/9/17

Reg. No. M.1670 P.C. 17640

16th September, 1977.

Mrs. Margaret Proctor, Cortium, Brittas, Co. Dublin.

Re/ Proposed septic tank at Gortlum, Brittas, for Mrs. Margaret Proctor.

Dear Madam,

With reference to your planning application received on 18th July, 1977, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Act, 1963, the following information must be submitted in quadruplicatess

1. A block plan to a scale of 1:500 showing accurately the position of the house and the proposed location of the septic tank in compliance with the Council's distance requirements for septic tanks; these are:-

(a) 60° (not more or less) from the house.

(b) at least 60' from road boundaries.

(c) at least 150° from any well, spring or similar source of potable water.

(d) at least 300' from any other septic tank or approved septic

tank position.

 An acceptable septic tank design must be submitted. The soakpit shown on the plan submitted on 18/7/77 must be omitted and the effluent disposed of directly into the soil. A reserve septic tank effluent percolation must be provided.

3. Evidence of the availability of an adequate water supply suitable

for drinking and senitary purposes.

N.B. The applicant is advised to consult with the Health Inspectors for the area before submitting additional information.

Please mark your reply "Additional Information" and quote the Register reference number given above.

Yours faithfully,

juic

for Senior Administrative Officer.