

COMHAIRLE CHONTAE ÁTHA CLIATH

File Reference P.C. 11226	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 PLANNING REGISTER		REGISTER REFERENCE M.1807
1. LOCATION	Kilken Road, Dublin, 10.		
2. PROPOSAL	Water cooling tower		
3. TYPE & DATE OF APPLICATION	TYPE P. Date Received 11th July, 1977	Date Further Particulars (a) Requested 1. _____ 2. _____ (b) Received 1. _____ 2. _____	
4. SUBMITTED BY	Name Golden Vale Engineering, E. G. Pettit & Co., Address Charleville, Co. Cork, Shelbourne Road, Dublin, 2.		
5. APPLICANT	Name Samperit (Ireland) Limited, Address Kilken Road, Dublin, 10.		
6. DECISION	O.C.M. No. P/3225/77 Date 8/9/77	Notified 9th September, 1977 Effect To Grant Permission	
7. GRANT	O.C.M. No. P/3857/77 Date 7/11/77	Notified 7th November, 1977 Effect Permission Granted	
8. APPEAL	Notified Type	Decision Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
16.			
Prepared by _____		Copy issued by _____ Registrar.	
Checked by _____		Date _____	
Grid Ref.	O.S. Sheet	Co. Accts. Receipt No. _____	

DUBLIN COUNTY COUNCIL

P/3857/H

Tel. 742951 (Ext. 131)

PLANNING DEPARTMENT,
46-49 DAME STREET,
DUBLIN 2

Notification of Grant of Permission/Approval
Local Government (Planning and Development) Act, 1963

To:

O'Reilly Hyland, Tierney & Associates,
2, Upper Pembroke Street,
Dublin 2.

Decision Order Number and Date **P/3223/77, 8/9/77.**

Register Reference No. **M.1807**

Planning Control No. **11226**

Application Received on **11/7/77.**

Applicant: **Imperial (Ireland) Limited**

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.
proposed water cooling tower at Killash Road, Dublin 10, etc

Conditions

1. Subject to the conditions of this permission, the development to be carried out and completed strictly in accordance with the plans and specification lodged with the application.
2. That the applicant ascertain and adhere to the requirements of the Building Bye-law Engineer.
3. That no overflow be permitted from the foul sewer to the surface water system.
4. That no connection, overflow or otherwise be permitted from the cooling water to surface water system.

Reasons for Conditions

1. To ensure that the development shall be in accordance with the permission and effective control maintained.
2. In order to comply with the Sanitary Services Acts, 1878-1964.
3. In order to comply with the Sanitary Services Acts, 1878-1964.
4. In order to comply with the Sanitary Services Acts, 1878-1964.

On behalf of the Dublin County Council:

[Signature]
Senior Administrative Officer

Form 4

Date: **7 NOV 1977**

The Council under Building Bye-Laws must be obtained before the development is carried out. The conditions of approval must be complied with in the carrying out of the work.