

File Reference P.C. 14943/13648		LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 PLANNING REGISTER		REGISTER REFERENCE K.1833
1. LOCATION		Ballybrack Road, Glencullen, Co. Dublin.		
2. PROPOSAL		Bungalow		
3. TYPE & DATE OF APPLICATION		TYPE P.	Date Received 26th July, 1976	Date Further Particulars
				(a) Requested 1. 24/9/76 2.
4. SUBMITTED BY		Name Mary Walsh, Address 77, Bawnville Road, Tallaght, Co. Dublin.		
5. APPLICANT		Name Mr. Patrick Jones, Address 29, Castle Lawns, Tallaght, Co. Dublin.		
6. DECISION		O.C.M. No. Date		Notified Effect
7. GRANT		O.C.M. No. Date		Notified Effect
8. APPEAL		Notified Type		Decision Effect
9. APPLICATION SECTION 26 (3)		Date of application		Decision Effect
10. COMPENSATION		Ref. in Compensation Register		
11. ENFORCEMENT		Ref. in Enforcement Register		
12. PURCHASE NOTICE				
13. REVOCATION or AMENDMENT				
14.				
15.				
16.				
Prepared by		Copy issued byRegistrar.		
Checked by		Date		
Grid Ref.	O.S. Sheet	Co. Accts. Receipt No.		

P/3200/76
24/9/76

Reg. No. K.1833
P.C. 14943/13648

24th September, 1976.

Mary Walsh,
77, Bawnville Road,
Tallaght,
Co. Dublin.

Re/ proposed bungalow at 187 Ballybrack Road, Glencullen,
Co. Dublin, for Mr. Patrick Jones.

A Chara,

With reference to your planning permission received on the 26th July, 1976, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Act, 1963, the following information must be submitted in quadruplicate:-

1. The applicant should submit a drawing showing the boundary of his site with the adjoining site to the east.
2. Revised plans are required which shall provide for safe access to the public road so as to eliminate any likely traffic hazard. The applicant should consider the possibility of combining his access with the access to the adjoining cottage to the east by providing a double gateway with a setback for road improvements on both. The applicant should consult with the Roads Design Department about these matters before any further plans are submitted.
3. The Supervising Health Inspector, Sanitary Authority, requires the applicant to relocate the proposed bungalow so that the septic tank is sited between the bungalow and the public road. The applicant should submit revised drawings in compliance with these and any other requirements of the Supervising Health Inspector, Sanitary Authority, 6, Parnell Square.
4. The applicant has given his address as 29, Castle Lawns, Tallaght, Co. Dublin. He is requested to submit evidence of his need for a house in the Glencullen area.

NOTE:- Please mark your reply "Additional Information" and quote the Register reference number given above.

~~Yours faithfully,~~

Mise, le meas,


for Senior Administrative Officer.