

COMHAIRLE CHONTAE ÁTHA CLIATH

File Reference P.C. 7620	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 PLANNING REGISTER		REGISTER REFERENCE K.1045
1. LOCATION	Bluebell, Dublin, 12. S		
2. PROPOSAL	Ext. to vehicle repair building		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
	P.	6/5/'76	1. 2.
4. SUBMITTED BY	Name	A. W. West, Esq.,	
	Address	25. Cambridge Road, Dublin, 6.	
5. APPLICANT	Name	Irish Ind. Gases Ltd.,	
	Address	Dublin, 12.	
6. DECISION	O.C.M. No.	P/2069/76	Notified 5th July, 1976
	Date	5/7/76	Effect To Grant Permission
7. GRANT	O.C.M. No.	P/2589/76	Notified 18th August, 1976
	Date	18/8/76	Effect Permission Granted
8. APPEAL	Notified	Decision	
	Type	Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision	
		Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
16.			

Prepared by

Checked by

Grid Ref.

O.S. Sheet

Copy issued byRegistrar.

Date

Co. Accts. Receipt No.....

DUBLIN COUNTY COUNCIL

2951 (Ext. 131)

PLANNING DEPARTMENT,
46-49 DAME STREET,
DUBLIN 2

Notification of Grant of Permission/Approval Local Government (Planning and Development) Act, 1963

To:

Decision Order Number and Date **p/2069/76 5th July '76**

Arthur W. West, B.A.I., M.I.E.I.,

Register Reference No. **K.1045**

Consulting Engineer,

Planning Control No. **7620**

25, Cambridge Road, Dublin 6.

Application Received on **6th May, 1976.**

Applicant: **Irish Industrial Gases, Ltd., Blueball, Dublin 12.**

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.
proposed extension to vehicle repair building at Blueball.

Conditions	Reasons for Conditions
<p>1. Subject to the conditions of this permission, the development to be carried out and completed strictly in accordance with the plans and specification lodged with the application.</p> <p>2. Before development commences, approval under the Building Bye-laws be obtained, and all conditions of that approval be observed in the development.</p> <p>3. The following requirements of the Chief Fire Officer to be adhered to in this development - (a) Alternative means of escape in case of fire from rear of building. (b) Wall beside boundary to be 1 hour fire resisting.</p> <p>4. That the applicant satisfy the Supervising Health Inspector of the Sanitary Authority that the development complies with the following requirements: (a) Compliance with Factories Act, 1955 and regulations made thereunder. The information must include indication on plan of adequate and suitable toilet facilities for male and female workers, with separately ventilated entrance lobbies. (b) Compliance with the Offices Premises Act, 1958 and regulations made thereunder. (c) Compliance with the Food Hygiene Regulations 1950/71. Extent of meals served to be stated, and if substantial meals are prepared, details on plan to be furnished, showing full compliance. (d) Compliance with control of atmospheric Pollution Regulations 1970. (e) Compliance with Sanitary Services Acts, 1948-62. All openings on drains within the building must be sealed off. Evidence must be furnished that there will be no pollution from trade processes, either liquid, gaseous, dust or otherwise.</p>	<p>1. To ensure that the development shall be in accordance with the permission and effective control be maintained.</p> <p>2. In order to comply with the Sanitary Services Acts, 1878-1964.</p> <p>3. In the interest of public safety and avoidance of fire hazard.</p> <p>4. In order to comply with the Sanitary Services Acts 1878-1964.</p>

Continued.

behalf of the Dublin County Council:

for **Senior Administrative Officer**

Form 4

Date: **18th August, 1976.**

Approval of the Council under Building Bye-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.