

Reg

S

p/25/71
(8/1/71)

C. 1849

P.C. 13283

8th January, 1971

Patrick Hanley, Esq.,
10 Newlands Drive,
Clondalkin,
Co. Dublin

Re: Proposed bungalow at Commons, Rathcoole, for
Theresa Kilgallon

A Chara,

With reference to your Planning Application received on the 13th November, 1970, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Act, 1963, the following information must be submitted in triplicate:-

1. Revised plans are required providing for (a) adequate site curtilage for septic tank drainage, (b) adequate clearances of septic tank from adjoining properties together with any necessary trial holes that may be required.

2. Revised plans are also required providing for adequate and safe access for the purposes of avoiding any possible traffic hazard.

Note:-

The applicant is advised to consult with the Chief Medical Officer's Department, and Roads Department, 6 Parnell Square in connection with the above matters before submitting any revised plans.

Mise, le Meas,

Dr

a.s. Príomh Oifigeach