

V/1192/69.

Reg. B.823.

22 Iul, 1969.

Walter Brennan, Esq.,  
Lissadell,  
Corballis,  
Donabate,  
CO. DUBLIN.

S

Re: Proposed dwelling at Peamount Road, Newcastle.

A Chara,

With reference to your letter dated 4th June, 1969, regarding planning permission in connection with the above, I am to inform you that before the application can be considered under the Local Government (Planning and Development) Act, 1963, the following information must be submitted in triplicate:-

- (1) A site plan should be submitted showing the proposed site more accurately and in relation to adjoining development.
- (2) Revised plans are required providing for the location and excavation of satisfactory trial holes after consultation and agreement with the Sanitary Authority, 6, Parnell Square, Dublin 1, with regard to the proposed method of providing septic tank drainage for the development.

Mise, le mees,

  
a.s. Príomh Oifigeach.

