

Reg
P/1225/69

Reg. B. 820.

31st July, 1969.

Anthony Noble, Esq.,
49, Connolly Avenue,
Inchicore,
CO. DUBLIN.

RE: PROPOSED BUNGALOW AT SAGGART FOR A. NOBLE.

A Chara,

With reference to your letter dated 3rd June, 1969, regarding planning permission in connection with the above, I wish to inform you that before your application can be considered under the Local Government (Planning and Development) Act, 1963, the following information must be submitted in triplicate :-

- (1) Revised plans are required providing for the location and excavation of satisfactory trial holes after consultation and agreement with the Sanitary Authority, 6, Parnell Square, with regard to the proposed method of providing septic tank drainage for the development.
- (2) Revised plans are required providing for the relocation of well and septic tanks so as to ~~give~~ a separation between of at least 150-ft.
- (3) Revised plans are required providing for a minimum set back of 30ft. from the public road.

Wise, ie meas,

a.s. Páircín Oifigeach.

