

Plan Number 9029/	DUBLIN COUNTY COUNCIL Local Government (Planning and Development) Act, 1963 REGISTER (Part I)				NOTE. Plans complying with conditions of P/331/67. recd. 28/8/67 Folio 3489/		
1. LOCATION	Oldbawn Road, Tallaght.						O.S. No.
2. PROPOSAL Subject of Application	Temporary Sewerage Disposal works for Housing Scheme.						Grid Ref.
3. APPLICATION Type and Date	Type of Application	Application Date	Further Particulars Requested		Further Particulars Received		
	Permission	6-4-67	1		2		
4. SUBMITTED BY Name and Address	Name: Diamond Redfern Anderson, Aechs Address: 31 Le. Baggot St, Dublin 2.						
5. PROPOSER'S NAME AND ADDRESS	Name: Jancy Estates Ltd. Address: Kildare St, Dublin 2.						
6. DECISION	O.C.M. & Date	Notified	Effect			S.26(2) (e)	S.26(2) (g)
	33/ 2/6/67	2/6/67	To grant permission - 9c.				S.26(2) (h)
7. GRANT	Date of Grant	Sent	Effect			S.26(2) (e)	S.26(2) (g)
	14-7-67	20-7-67.	Permission granted - 9c.				S.26(2) (h)
8. APPEAL	Notification to Co. Council	DATE OF MINISTER'S DECISION	Effect of Decision of Minister				
9. S.26(3) APPLICATION	DATE OF APPLICATION	DATE OF MINISTER'S DECISION	Effect of Decision of Minister				
10. COMPENSATION	Claim		Ref. in Part II. (Compensation Register)				
11. ENFORCEMENT	Section		Ref. in Part III. (Enforcement Register)				
12. PURCHASE NOTICE							
13. REVOCATION OR AMENDMENT							
14.							
15.							
16.							
Date of Issue of copy Registrar Co. Accountant's Receipt No.							

- (1) That the development be carried out in strict conformity with the plans and specifications lodged with the application.
- (2) That the nearest point of percolation area is located at a minimum distance of 150-ft from the River Dodder.
- (3) That the outlet levels of the plant are arranged to enable a satisfactory link-up by gravity to the proposed Dodder Valley sewer.
- (4) That the capacity, design, construction, operation and maintenance of the proposed works be in accordance with the requirements of the County Council.
- (5) That a legally binding agreement be entered into between the applicant and the Dublin County Council, whereby at the applicant's expense, the County Council will maintain the proposed temporary sewerage treatment works, the details of which have yet to be agreed by the County Council, until such time as the outfall pipe from the development is connected onto the proposed Dodder Valley trunk sewer.
- (6) That the conditions (2), (3), (4), (5) and (6) specified in the decision to grant outline permission for the housing development by order No. P/1253/66, dated - 19th December 1966 be adhered to.
- (7) Cognisance should be taken of the Council's proposal to lay the main trunk Dodder Valley sewer through portion of the site. For this purpose a wayleave will be required by the Council, which should be provided for the developer. (Particulars of the location and other details of this trunk sewer may be obtained from the Sanitary Services Section of the County Engineer's Department).
- (8) That the proposed treatment plant and disposal works be suitably landscaped to the satisfaction of the County Council.
- (9) That Building Bye-laws approval shall be obtained and any conditions of approval shall be observed in the development.