

B

Meehan Levins Delaney,
Edward Street,
Newbridge,
Co. Kildare.

87B/96

4/6/'87

Re: Proposed septic tank at Dale View, Palmerstown,
Dublin 20 for D. Bruton.

Dear Sirs,

I refer to your submission received on 8/4/'87, to comply with condition No. 2 of decision to grant permission by Order No. P/1112/87, dated 8/4/'87, in connection with the above.

In this regard, I wish to inform you that the submission is in compliance with Condition No. 2 subject to the following requirements of the Supervising Environmental Health Officer being adhered to:-

- 1) A two compartment septic tank shall be provided in accordance with I.I.R.S. S.R. 6 1975 recommendations;
- 2) A distance of at least 150ft. being provided between proposed septic tank and any existing septic tank.

Yours faithfully,

J. deB
for Principal Officer.

COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE 87B/96
1. LOCATION	Dale View, Palmerstown, Dublin 20.		
2. PROPOSAL	Septic tank		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars
			(a) Requested (b) Received
	P.	10 February 1987	1. 2.
4. SUBMITTED BY	Name Meehan Levins Delaney Address Edward Street, Newbridge, Co. Kildare.		
5. APPLICANT	Name Des Bruton Address Dale View, Palmerstown, Dublin 20.		
6. DECISION	O.C.M. No. P/1112/87		Notified 8/4/87
	Date 8/4/87		Effect To grant permission
7. GRANT	O.C.M. No. P/1745/87		Notified 19th May, 1987
	Date 19th May, 1987		Effect Permission granted.
8. APPEAL	Notified		Decision
	Type		Effect
9. APPLICATION SECTION 26 (3)	Date of application		Decision
			Effect
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			

Prepared by

Checked by

Copy issued by Registrar.

Date

Co. Accts. Receipt No

B

Meehan Levins Delaney,
Edward Street,
Newbridge,
Co. Kildare.

87B/96

4/6/'87

Re: Proposed septic tank at Dale View, Palmerstown,
Dublin 20 for D. Bruton.

Dear Sirs,

I refer to your submission received on 8/4/'87, to comply with condition No. 2 of decision to grant permission by Order No. P/1112/87, dated 8/4/'87, in connection with the above.

In this regard, I wish to inform you that the submission is in compliance with Condition No. 2 subject to the following requirements of the Supervising Environmental Health Officer being adhered to:-

- 1) A two compartment septic tank shall be provided in accordance with I.L.R.S. S.R. 6 1975 recommendations;
- 2) A distance of at least 150ft. being provided between proposed septic tank and any existing septic tank.

Yours faithfully,

J. DeB
for Principal Officer.

DUBLIN COUNTY COUNCIL

Tel 724755 (ext 262/264)

P/1.7.45/87

PLANNING DEPARTMENT
IRISH LIFE CENTRE,
41 ABBEY STREET,
DUBLIN 1

Verification of Grant of Permission/Approval

Land Development (Planning and Development) Acts, 1963-1983

To: **Michael Lovins February,**
Edward Street,
Newbridge,
Co. Kildare.
Applicant **D. Bruhan**

Decision Order **P/1112/87 - 0/4/87**
Number and Date
Register Reference No. **87B-96**
Planning Control No.
Application Received on **10/2/87**
Floor Area

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.

Septic tank at Dale View, Palmerstown, Dublin 20.

CONDITIONS	REASONS FOR CONDITIONS
1. The development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.	1. To ensure that the development shall be in accordance with the permission and that effective control be maintained.
2. That the septic tank drainage arrangements be in accordance with the requirements of the Supervising Environmental Health Officer. In this regard, the length of piping in the main percolation area shall be at least 15 metres; and a reserve percolation area shall be provided.	2. In order to comply with the requirements of the Supervising Environmental Health Officer.

Signed on behalf of the Dublin County Council

AK
For Principal Officer

Date: **19 MAY 1987**

Approval of the Council under Building By-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.