

COMHAIRLE CHONTAE ATHA CLIATH

P. C. Reference		LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE 86A/1575
1. LOCATION		The Laurels, Public House, Main Street, Clondalkin		
2. PROPOSAL		Extension and modifications to toilets		
3. TYPE & DATE OF APPLICATION		TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
		P.	13 November 1986	1. 9/1/87 2.
4. SUBMITTED BY		Name James V. N. Looney Address 17 Prussia Street, Dublin 7.		
5. APPLICANT		Name L. Fitzgerald Address The Laurels, Main Street, Clondalkin		
6. DECISION		O.C.M. No. Date	Notified Effect	
7. GRANT		O.C.M. No. Date	Notified Effect	
8. APPEAL		Notified Type	Decision Effect	
9. APPLICATION SECTION 26 (3)		Date of application	Decision Effect	
10. COMPENSATION		Ref. in Compensation Register		
11. ENFORCEMENT		Ref. in Enforcement Register		
12. PURCHASE NOTICE				
13. REVOCATION or AMENDMENT				
14.				
15.				
Prepared by		Copy issued by Registrar.		
Checked by		Date		
		Co. Accts. Receipt No		

James V.N. Looney,
Civil & Structural Engineer,
17 Prussia Street,
Dublin 7

86A/1575

9.1.87

RE/ Proposed extension and modifications to toilets and proposed kitchen at
The Laurels Public House, Clondalkin for L. Fitzgerald

Dear Sir,

With reference to your planning application received here on the 13.11.86 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963-1983 the following additional information must be submitted in quadruplicate:-

1. The applicant is requested to submit a block plan on a scale of 1:250 or equivalent showing a complete site car parking layout with car parking bays, circulation areas etc.
2. The applicant is requested to submit acceptable surface water drainage details. No surface water is to be discharged to the foul sewer system.
3. The proposed development does not comply with the provisions of the Food Hygiene Regulations 1950/71. Internally located gullies in the food room are not acceptable. Staff w.c. and staff cloakroom are not shown on plan. In this regard, the applicant is advised to consult with the Supervising Environmental Health Officer.

Please mark your reply 'Additional Information' and quote the Reg. Ref. No. given above.

Yours faithfully,


for Principal Officer.