## COMHAIRLE CHONTAE ATHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING DEVELOPMENT) ACT 1963 & 19			G AND 1976	REGISTER REFERENCE XA.1052
1 LOCATION		PLANNING REGISTER			
1. LOCATION	Ballymanaggin, Clondalkin, Co. Dublin				
2. PROPOSAL	Advanced construction of block 6 in six factory/Warehousing units, with ancillary offices, along with associated site development				
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	(a) Requ		ner Particulars (b) Received
	P	31/5/82	1		2
4. SUBMITTED BY	Name Petrus Developments Ltd.,  Address Greenhills Industrial Estate, Greenhills Rd,  Walkinstown, Dublin 12				
5. APPLICANT	Name Falkland Company Ltd.,  Address C70 Petrus Developments Ltd				
6. DECISION	O.C.M. No		CATION	Notified WTTHDRAWN Effect	
7. GRANT	O.C.M. No	•		Notified Effect	
8. APPEAL	Notified Type			Decision Effect	
9. APPLICATION SECTION 26 (3)	Date of application			Decision Effect	
10. COMPENSATION	Ref. in Compensation Register				
11. ENFORCEMENT	Ref. in Enforcement Register				
12. PURCHASE NOTICE					
13. REVOCATION or AMENDMENT		<u></u>	i.		
14.					
15.				<u> </u>	Regis
Prepared by					
Future Print 475588	<u> </u>		pt No		> 24464

Future Print 475588

27th August, 1982.

Petrus Developments,
Greenhills Industrial Estate,
Greenhills Road,
Walkinstown,
Dublin 12.

Re: Proposed advanced construction of block 6 in six factory
warehousing units with ancillary offices, along with associated
site development at Crag Crescent, Clondalkin Industrial Estate,
Ballymanaggin, for Falkland Co. Ltd.

Dear Sirs,

I refer to your letter of the 25th August, 1982 and note that you have withdrawn the above planning application, which was lodged in this Department on the 31st May, 1982.

Yours faithfully,

for Principal Officer

30th July, 1982.

Petrus Developments, Greenhills Industrial Estate, Greenhills Road, Walkinstown, DUBLIN 12.

RE: Proposed advanced construction of block 6 in six factory warehousing units, with ancillary offices, along with associated site developments, at Crag Crascent Clondalking Industrial Estate, Ballymanaggin, for Falkland Company Ltd.

Dear Sir,

With reference to your planning application received here non 31st May, 1982 in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. The applicant should indicate if he is in a position to satisfy the requirements of the Sanitary Services Engineer in relation to foul sewer facilities. The proposed block, on the submitted plans, is indicated too close to a County Council trunk sewer which truverses the site. The applicant should submit plans indicating the proposed block in relation to the sewer. No building is to be located within 5m. of the centre line of the sewer.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,

for Principal Officer.