

COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE XA.1032.
1. LOCATION	Hynestown, Newcastle. S		
2. PROPOSAL	Bungalow.		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
	P	28.5.1982.	1. 27th July, '82 2.
4. SUBMITTED BY	Name J. Fitzsimons. Address Kells Art Studios, John St., Kells, Co. Meath.		
5. APPLICANT	Name L. Deane. Address 30 Forest Park, Leixlip, Co. Kildare.		
6. DECISION	O.C.M. No.	Notified	
	Date	Effect	
7. GRANT	O.C.M. No.	Notified	
	Date	Effect	
8. APPEAL	Notified	Decision	
	Type	Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision	
		Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			

Prepared by
 Checked by

Copy issued by Registrar.
 Date
 Co. Accts. Receipt No

XA.1032

27th July, 1982.

Mr. Liam Deane,
30, Forest Park,
Leixlip,
Co. Kildare.

Re: Proposed bungalow and septic tank at Hynestown, Newcastle
for L. Deane.

Dear Sir,

With reference to your planning application received here on 28/5/'82 in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. The submitted proposals for septic tank drainage are unacceptable in that a dual septic tank system is not acceptable and it would appear that the site proposed is too small to comply with the County Council's distance requirements with regard to septic tanks and the provision of percolation and reserve percolation areas. The County Council requires that septic tank drainage for developments such as that proposed should be in accordance with the I.L.R.S. Recommendations SR6 of 1975. The applicant should indicate if he/she is in a position to provide for the requirements of the County Council in relation to drainage for the existing and proposed bungalow. Note: The applicant is advised to consult with the Supervising Health Inspector, Eastern Health Board prior to re-submission.

Please mark your reply "Additional information" and quote the Reg. Ref. No. given above.

Yours faithfully,=


for Principal Officer