

COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE 85A/1519
1. LOCATION	Townlands of Gallanstown, Raheen, Collinstown & Blackditch		
2. PROPOSAL	Overhead Electric Line		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
	P	25 November '85	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> 1. 2. </div> <div style="width: 45%;"> 1. 2. </div> </div>
4. SUBMITTED BY	Name J.F. Williams, Secretary, E.S.B., Address Lower Fitzwilliam Street, Dublin 1		
5. APPLICANT	Name E.S.B. Address		
6. DECISION	O.C.M. No.	P/180/86	Notified 23rd Jan., 1986
	Date	23rd Jan., 1986	Effect To grant permission
7. GRANT	O.C.M. No.	P/756/86	Notified 5th March, 1986
	Date	5th March, 1986	Effect Permission granted
8. APPEAL	Notified		Decision
	Type		Effect
9. APPLICATION SECTION 26 (3)	Date of application		Decision
			Effect
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			

Prepared by

Checked by

Copy issued by Registrar.

Date

Co. Accts. Receipt No

85A-1519

E.S.B.,
c/o J.F. Williams, Sec.,
Lower Fitzwilliam Street,
Dublin 2.

6th June, 1986.

RE: Proposed erection of an overhead electric line in the townlands of Gallanstown, Raheen, Collinstown and Blackditch, near the town of Clondalkin for J.F. Williams, Sec., E.S.B.

Dear Sir,

I refer to your submission received on 2nd April, 1986, to comply with condition No. 3 of decision to grant permission by Order No. P/180/86, dated 23rd January, 1986, in connection with the above.

In this regard, I wish to inform you that the applicant is required to re-consult with the Sanitary Services Department with regard to the siting of the proposed electricity line and ancillary pylons. In this regard, trial holes are to be dug to locate the exact position of the 450mm watermain, where pylon masts are located in close proximity to the watermain.

The applicant should further note the following:

1. Required clearance being provided where the line crosses the road. A 2m. clearance from the tower accommodates switching serged on high voltage lines. Therefore, Roads would require a minimum clearance of 8m over finished road level, where the line crosses the road.
2. Alignment being as shown on lodged drawings and to be agreed on site with Roads Department.
3. The line is shown crossing the proposed road where the road will be bridging the railway line. Applicant should re-route this line to cross when the roadway is at ground level. This should be done following consultation with the Roads Department.

If this item is not complied with applicant will have to re-route the line at their own expense when the bridge is being built.

Yours faithfully,



for Principal Officer.

DUBLIN COUNTY COUNCIL

724755 (ext. 262/264)

PLANNING DEPARTMENT,
BLOCK 2,
IRISH LIFE CENTRE,
LR. ABBEY STREET,
DUBLIN 1.

GRANT OF
PERMISSION

P / 7.5.6 / 86

Notification of Grant of Permission/Approval
Local Government (Planning and Development) Acts, 1963-1983

To E.S.B.,
c/o, J.F. Williams, Sec.,
Lower Fitzwilliam Street,
Dublin 2.
Applicant J.F. Williams, Sec., E.S.B.

Decision Order
Number and Date P/180/86, 23/1/'86
Register Reference No. 85A/1519
Planning Control No.
Application Received on 25/11/'85

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.

Proposed erection of an overhead electric line in the townlands of Callanstown, Rahen,
Collinstown and Blackditch, near the town of Clondalkin.

CONDITIONS	REASONS FOR CONDITIONS
1. That the development to be carried out in its entirety in accordance with the plans, particulars and specifications lodged with the application, save as may be required by the other conditions attached hereto.	1. To ensure that the development shall be in accordance with the permission, and that effective control be maintained.
2. That no pylon be erected within 5m. of the existing east/west foul and surface water sewers at the northern end of this proposal.	2. In the interest of the proper planning and development of the area.
3. That the E.S.B. consult with the water supply section of the Sanitary Services Department regarding their requirements in relation to the position of existing and proposed watermains along the route of the E.S.B. Line. The precise location of the line shall be determined in agreement with this section and with the Planning Department.	3. In the interest of the proper planning and development of the area.
4. That the applicant agree the precise location of line through Dublin Corporation lands with Dublin Corporation.	4. To ensure a satisfactory standard of development.

Signed on behalf of the Dublin County Council

[Signature]
For Principal Officer

Date 5 MAR 1986

Approval of the Council under Building Bye-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.