

# COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE XA 711
1. LOCATION	Piperstown, Tallaght, <span style="font-size: 2em; float: right;">S</span>		
2. PROPOSAL	Septic tank		
3. TYPE & DATE OF APPLICATION	TYPE  P	Date Received  13th April, 1982	Date Further Particulars (a) Requested
			(b) Received
			1. 11th June, 1982
			1. ....
			2. ....
4. SUBMITTED BY	Name Kieran Taylor, Address		
5. APPLICANT	Name Thomas McGrath, Address Piperstown, Tallaght, Co. Dublin.		
6. DECISION	O.C.M. No. PA/3184/82		Notified 21st Dec., 1982
	Date 21st Dec., 1982		Effect To refuse permission,
7. GRANT	O.C.M. No.		Notified
	Date		Effect
8. APPEAL	Notified		Decision
	Type		Effect
9. APPLICATION SECTION 26 (3)	Date of application		Decision
			Effect
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
Prepared by .....		Copy issued by ..... Registrar.	
Checked by .....		Date .....	
		Co. Accts. Receipt No .....	

# DUBLIN COUNTY COUNCIL

Phone 724755  
Ext. 262/264

PLANNING DEPARTMENT  
Block 2  
Irish Life Centre  
Lower Abbey Street  
Dublin 1

## NOTIFICATION OF A DECISION TO REFUSE:

~~OUTLINE PERMISSION:~~ PERMISSION: ~~APPROVAL~~  
~~XXXXXXXXXXXXXXXXXXXX~~ ~~IN BLOCK~~  
LOCAL GOVERNMENT (PLANNING & DEVELOPMENT) ACTS, 1963 & 1976

To;

K. Taylor,

108 Templeogue Wodd,

Dublin, 12.

Register Reference No. .... **XA.711** .....

Planning Control No. .... **14265** .....

Application Received .... **13/4/82** .....

Additional Inf. Recd. .... **1/11/82** .....

APPLICANT .. **T. McGrath** .....

In pursuance of its functions under the above mentioned Acts the Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by order, P/A/3184/82..... dated **21st December, 1982.** decide to refuse:

~~OUTLINE PERMISSION~~  
~~XXXXXXXXXXXXXXXXXXXX~~

PERMISSION

~~APPROVAL~~  
~~XXXXXXXXXXXX~~

For... **proposed septic tank at Piperstown, Talaght** .....

for the following reasons:

1. The existing septic tank is not functioning properly, its percolation and reserve percolation areas are not satisfactory in relation to adjoining installations, and the development would be likely to cause contamination of adjoining water supply sources. The development would thus not be in accordance with the proper planning and development of the area, would seriously injure the amenities of residential property in the vicinity and would be prejudicial to public health.

Signed on behalf of the Dublin County Council .....

for PRINCIPAL OFFICER

Date... **21st December, 1982.** .....

NOTE: An appeal against the decision may be made to An Bord Pleanala by the applicant within one month from the date of receipt by the applicant of this notification or by any other person within twenty-one days of the date of the decision. The appeal shall be in writing and shall state the subject matter of the appeal and grounds of the appeal and should be addressed to An Bord Pleanala, Irish Life Centre, Dublin 1, and accompanied by a deposit of £10. When an appeal has been duly made and has not been withdrawn, An Bord Pleanala will determine the application for permission as if it had been made to them in the first instance.

FUTURE PRINT

XA 711

11th June. 1982.

T. McGrath,  
Piperstown,  
Tallaght,  
Co. Dublin.

RE: Proposed septic tank at Piperstown, Tallaght for T. McGrath.

Dear Sir,

With reference to your planning application received here on 13th April, 1982, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning & Development) Acts, 1963 & 1976 the following additional information must be submitted in quadruplicate:-

1. Further information is required which should provide for:-  
Clarification that adequate and satisfactory septic tank drainage system can be provided which is acceptable to Dublin Corporation Waterworks Department and that will not cause contamination or pollution to adjoining stream courses.

NOTE: The applicant is advised to consult with Dublin Corporation Waterworks Department and the County Council before submitting any further information.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,

  
\_\_\_\_\_  
for Principal Officer.