

# COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 <b>PLANNING REGISTER</b>		REGISTER REFERENCE <b>XA.98.</b>
1. LOCATION	Athgoe, Newcastle. <span style="float: right; font-size: 2em;">S</span>		
2. PROPOSAL	House.		
3. TYPE & DATE OF APPLICATION	TYPE  P	Date Received  26.1.1982.	Date Further Particulars (a) Requested (b) Received
			<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> 1. 24th March, 1982  .....  2. .... </div> <div style="width: 45%;"> 1. ....  .....  2. .... </div> </div>
4. SUBMITTED BY	Name <b>Mr. E. Logan.</b> Address <b>Athgoe, Newcastle.</b>		
5. APPLICANT	Name <b>Mr. E. Logan.</b> Address .....		
6. DECISION	O.C.M. No.  Date	Notified  Effect	
7. GRANT	O.C.M. No.  Date	Notified  Effect	
8. APPEAL	Notified  Type	Decision  Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision  Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			

Prepared by .....

Checked by .....

Copy issued by ..... Registrar.

Date .....

Co. Accts. Receipt No .....

XA 98

24th March, 1982.

Mr. Edward Logan,  
Athgoe,  
Newcastle,  
Co. Dublin.

---

Re: Proposed erection of dwelling at Athgoe, Newcastle for  
Edward Logan.

---

Dear Sir,

With reference to your planning application received here on 26/1/82 in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. A public piped water supply is not available to serve the proposed development. The applicant is to submit information giving details of an alternative water supply if feasible.
2. The applicant is to submit information with regard to the following:-
  - a. ~~Evidence~~ is to be submitted in regard to the suitability of soil for the disposal of septic tank effluent. A trial hole 1m. x 1m. x 2m. deep must be opened on the site.
  - b. Septic tank design plans are to be submitted and the percolation area is to be shown.


The applicant is to consult with the Health Inspector before re-submitting.

3. The applicant is to show how he can provide a safe access with adequate vision splays. The entrance gates should be recessed to a depth of 15ft. from the site boundary with wing walls splayed at 45°. The site is also affected by road proposals. The reservation for this is to be agreed with the Roads Engineers.

The applicant is to consult with Roads Department on the above matters.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,

  
\_\_\_\_\_  
for Principal Officer.