

# COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE  WA. 1922.
1. LOCATION	Palmerstown Upper, Co. Dublin. <span style="font-size: 2em; float: right;">S</span>		
2. PROPOSAL	Revised house type on sites 1-55 incl.		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
	P	24/9/1981	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> 1. 23rd Nov., 1981  .....  2. .... </div> <div style="width: 45%;"> 1. ....  .....  2. .... </div> </div>
4. SUBMITTED BY	Name Keenan, FitzGerald & Associates.		
	Address Herbert House, 4, Herbert Place, D.2.		
5. APPLICANT	Name Mr. John Dolan.		
	Address 117, Barton Road East, D.14.		
6. DECISION	O.C.M. No.		Notified
	Date		Effect
7. GRANT	O.C.M. No.		Notified
	Date		Effect
8. APPEAL	Notified		Decision
	Type		Effect
9. APPLICATION SECTION 26 (3)	Date of application		Decision
			Effect
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			

Prepared by .....

Checked by .....

Copy issued by ..... Registrar.

Date .....

Co. Accts. Receipt No .....

WA.1922

23rd November, 1981.

Keenan, Fitzgerald & Assoc.,  
4, Herbert Place,  
Dublin 2.

Re: P.C. 9493: Proposed revised house type on sites  
1 to 55 inclusive, previously approved at Palmerstown  
Upper for John Dolan.

Dear Sir/Madam,

With reference to your planning application received here on 24th September, 1981 in connection with the above, I wish to inform you, that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. An accurate block plan at 1:500 or similar scale of the development is required indicating the proposed houses on sites. In this regard it is noted that the block plan submitted does not properly indicate the house type shown on house plan drawings.
2. In relation to foul drainage the applicant must submit written permission from the owner of lands outside the boundary of the site across which the sewer outfall will be laid.
3. In relation to surface water drainage a sewer is unavailable as proposed. The applicant must submit alternative proposals together with acceptable run off calculations and longitudinal sections indicating levels, gradients and pipe sizes. Written evidence of any new wayleaves required should also be submitted. Applicant is advised to consult with Sanitary Services Department.
4. Clarification is required as to applicant's intentions with regard to the area of land adjacent to the side of sites 10, 11 and 39.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,

  
\_\_\_\_\_  
for Principal Officer.