

COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference		LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE WA 1556	
1. LOCATION		Lucan Boys Nat. School, Chapel Hill, Lucan, S			
2. PROPOSAL		Two storey extension,			
3. TYPE & DATE OF APPLICATION		TYPE	Date Received	Date Further Particulars (a) Requested (b) Received	
		P	5th August, 1981	1. 2nd Oct., 1981 2.	1. 13th Nov., 1981 2.
4. SUBMITTED BY		Name Louis J. Brennan, Address 75, Eglinton Road, Donnybrook, Dublin 4.			
5. APPLICANT		Name Rev. L. Quinlan, Address The Presbytery, Lucan, Co. Dublin.			
6. DECISION		O.C.M. No. PA/45/82 Date 12th Jan., 1982		Notified 12th Jan., 1982 Effect To grant permission,	
7. GRANT		O.C.M. No. PBD/142/82 Date 2nd March, 1982		Notified 2nd March, 1982 Effect Permission granted,	
8. APPEAL		Notified Type		Decision Effect	
9. APPLICATION SECTION 26 (3)		Date of application		Decision Effect	
10. COMPENSATION		Ref. in Compensation Register			
11. ENFORCEMENT		Ref. in Enforcement Register			
12. PURCHASE NOTICE					
13. REVOCATION or AMENDMENT					
14.					
15.					
Prepared by		Copy issued by Registrar.			
Checked by		Date			
		Co. Accts. Receipt No			

DUBLIN COUNTY COUNCIL

PBD/ 142/82

Tel. 724755(Ext. 262/264)

PLANNING DEPARTMENT
DUBLIN COUNTY COUNCIL
IRISH LIFE CENTRE
LOWER ABBEY STREET
DUBLIN 1

Notification of Grant of Permission/Approval Local Government (Planning and Development) Acts, 1929-1976

To:

Mr. Louis J. Brennan,
75, Linton Road,
Dennybrook,
Dublin 4.

Decision Order
Number and Date

PA/45/82, 12/1/82

Register Reference No.

WA.1556

Planning Control No.

9155

Application Received on

5/9/81

Additional Inf. Rec'd. 13/11/81

Applicant

Rev. L. Quinlan

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.

XXXXXX

Proposed two storey extension to Lucan Boys National School at Chapel Hill,
Lucan.

CONDITIONS

1. Subject to the conditions of this permission the development be carried out and completed strictly in accordance with the plans and specification lodged with the application.
2. That before development commences approval under the Building Bye Laws to be obtained and all conditions of that approval to be observed in the development.
3. That the requirements of the Chief Medical Officer be ascertained and strictly adhered to in the development.
4. That the requirements of the Chief Fire Officer be ascertained and strictly adhered to in the development.
5. That the water supply and drainage arrangements be in accordance with the requirements of the Sanitary Authority. In this respect adequate protection to be given to any sewers situated under or close to any buildings.
6. That car parking to Development Plan Standards be provided to serve the existing and proposed development.

REASONS FOR CONDITIONS

1. To ensure that the development shall be in accordance with the permission and that effective control be maintained.
2. In order to comply with the Sanitary Services Acts, 1878-1964.
3. In the interest of public health.
4. In the interest of safety and the avoidance of fire hazard.
5. In order to comply with the requirements of the Sanitary Authority.
6. In order to comply with the requirements of Development Plan Standards.

Signed on behalf of the Dublin County Council:

for Principal Officer

Date:

2 MAR 1982

Approval of the Council under Building Bye-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.

FUTURE PRINT

WA 1556

2nd October, 1981.

Louis J. Brennan Inc.,
75, Eglinton Road,
Donnybrook,
Dublin 4.

RE: Proposed two storey extension to Lucan Boys National School at
Chapel Hill, Lucan, for Rev. J. Quinlan.

Dear Sir,

With reference to your planning application received here on 5th August, 1981, in connection with the above I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1986 the following additional information must be submitted in quadruplicate:-

1. The applicant should indicate how he can satisfy the Sanitary Services Engineer in relation to foul sewerage facilities. The proposal is indicated over an existing 300mm foul sewer and the applicant should consult with the Sanitary Authority regarding provision of alternative proposals.
2. The applicant is requested to submit details of surface water outfall pipe in order to determine its capacity.
3. Details of off-street car parking for the existing school and proposed extension are required.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,


for Principal Officer.