

# COMHAIRLE CHONTAE ÁTHA CLIATH

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER		REGISTER REFERENCE  WA.1244
1. LOCATION	"Aisling", Westmanstown, Lucan		
2. PROPOSAL	Septic tank		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	Date Further Particulars (a) Requested (b) Received
	P.	22.6.81	1. 19th August, 1981
			2. ....
4. SUBMITTED BY	Name Mr. T. Cooke, Address 12 Pintwood Crescent, Ballymun, Dublin 11		
5. APPLICANT	Name Mr. C. O'Connor, Address "Aisling", Westmanstown, Lucan		
6. DECISION	O.C.M. No.  Date	Notified  Effect	
7. GRANT	O.C.M. No.  Date	Notified  Effect	
8. APPEAL	Notified  Type	Decision  Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision  Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
Prepared by .....		Copy issued by ..... Registrar.	
Checked by .....		Date .....	
		Co. Accts. Receipt No .....	

1932

WA 1244

19th August, 1981.

Mr. C. O'Connor,  
"Aisling",  
Westmanstown,  
Lucan,  
Co. Dublin.

RE: Proposed installation of septic tank at "Aisling", Westmanstown,  
Lucan, for Charles O'Connor.

Dear Sir,

With reference to your planning application received here on 22nd June, 1981, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. The Supervising Health Inspector reports that the percolation area is located too close to dwelling and that reserve percolation area has not been indicated. Applicant is asked to clarify whether or not he can overcome the objections raised by the Supervising Health Inspector.

NOTE: Applicant is advised to consult with Supervising Health Inspector in this regard.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours faithfully,

  
\_\_\_\_\_  
for Principal Officer.