

# COMHAIRLE CHONTAE ÁTHA CLIATH S

P. C. Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 <b>PLANNING REGISTER</b>		REGISTER REFERENCE  TA 2027
1. LOCATION	Site A31, Cherry Orchard Ind. Est., Ballyfermot Road,		
2. PROPOSAL	2 Ton capacity L.P.G. tank for fuelling private and commercial vehicles,		
3. TYPE & DATE OF APPLICATION	TYPE	Date Received	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> Date Further Particulars (a) Requested <b>23rd Dec., 1980</b> 1. .... 2. .... </div> <div style="width: 45%;"> (b) Received 1. .... 2. .... </div> </div>
4. SUBMITTED BY	Name	Calor Kosangas Ireland Ltd.,	
	Address	Lady's Well Brewery, Cork,	
5. APPLICANT	Name	James J. Murphy & Co. Ltd.,	
	Address	Lady's Well Brewery, Cork,	
6. DECISION	O.C.M. No.	Notified	
	Date	Effect	
7. GRANT	O.C.M. No.	Notified	
	Date	Effect	
8. APPEAL	Notified	Decision	
	Type	Effect	
9. APPLICATION SECTION 26 (3)	Date of application	Decision	
		Effect	
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
Prepared by .....		Copy issued by ..... Registrar.	
Checked by .....		Date .....	
		Co. Accts. Receipt No .....	

TA 2027

23rd December, 1980.

James J. Mupphy & Co. Ltd.,  
Lady's Well Brewery,  
Cork.

RE: Proposed L.P.G. Tank at site A31, Cherry Orchard Estate, Ballyfermot  
Road, Dublin, for James J. Murphy and Co., Ltd.

A Chara,

With reference to your planning application received here on 4th November, 1980, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. It is not clear from the lodged plans precisely where the proposed L.P.G. Tank is to be located on the site. Clarification of this matter is required.
2. The Chief Fire Officer is of the opinion that the tank should be located at least 25ft. from buildings and from boundaries. The Chief Fire Officer also considers that the tank should be surrounded by a 8ft. incombustible fence. Clarification is required as to whether or not applicant can conform to these requirements.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. given above.

Miss is mess,

  
\_\_\_\_\_  
for Principal Officer.