

# COMHAIRLE CHONTAE ÁTHA CLIATH

S

File Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 <b>PLANNING REGISTER</b>	REGISTER REFERENCE TA.1823
1. LOCATION	Blackchurch, Steelstown, Rathcoole, Co. Dublin	
2. PROPOSAL	Residence	
3. TYPE & DATE OF APPLICATION	TYPE	Date Received
		P.
		6.10.80
		Date Further Particulars
		(a) Requested (b) Received
		1. 4th Dec., 1980
		2. _____
4. SUBMITTED BY	Name Mr. P. Clarke, Address 1 Cremore Road, Glasnevin, Dublin	
5. APPLICANT	Name Mr. D. Vickers, Address Blackchurch, Rathcoole, Co. Dublin	
6. DECISION	O.C.M. No. PA/119/81	Notified 23rd Jan., 1981
	Date 22nd Jan., 1981	Effect To grant permission,
7. GRANT	O.C.M. No. PBD/86/81	Notified 5th Mar., 1981
	Date 5th Mar., 1981	Effect Permission granted,
8. APPEAL	Notified	Decision
	Type	Effect
9. APPLICATION SECTION 26 (3)	Date of application	Decision
		Effect
10. COMPENSATION	Ref. in Compensation Register	
11. ENFORCEMENT	Ref. in Enforcement Register	
12. PURCHASE NOTICE		
13. REVOCATION or AMENDMENT		
14.		
15.		
16.		

Prepared by .....	Copy issued by .....	Registrar.
Checked by .....	Date .....	
Grid Ref.	O.S. Sheet	Co. Accts. Receipt No. ....



Contd./....

the exception of the future 2nd house site and exist-  
ing house and surrounds) from further residential  
building in connection with this development before  
new house construction is commenced.

P.K.

230 ✓

TA 1823

4th December, 1980.

D. Vickers,  
Blackchurch,  
Rathcoole,  
Co. Dublin.

RE: Proposed residence on land at Steelstown, Rathcoole, for D. Vickers.

A Chere,

With reference to your planning application received here on 6th October, 1980, in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976, the following additional information must be submitted in quadruplicate:-

1. Further information is required which should provide for:-
  - a. A Block plan to a 1/500 scale showing positions of house, septic tank, well, percolation and reserve percolation areas. The septic tank position must be at least 150ft. from the well. These matters must be the subject of consultation and agreement with the Health Inspector's Department, Eastern Health Board, 33, Gardiner Place, Dublin 1, (727777), before the submission of further plans.
  - b. An indication of the location of the proposed second family house site (applicant's son) - taking into account the requirements set out in (a) above.

Please mark your reply "Additional Information" and quote the Reg. Ref. No. give above.

Miss le mess,

\_\_\_\_\_  
for Principal Officer.