

# COMHAIRLE CHONTAE ÁTHA CLIATH

File Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 <b>PLANNING REGISTER</b>		REGISTER REFERENCE  TA.86
1. LOCATION	Clondalkin Swimming Pool, Nangor Road, Clondalkin, Co. Dublin <span style="float: right; font-size: 2em;">3.</span>		
2. PROPOSAL	Oil tank at swimming pool		
3. TYPE & DATE OF APPLICATION	TYPE  P.	Date Received  21.1.80	Date Further Particulars
			(a) Requested (b) Received
			1. 2.
4. SUBMITTED BY	Name Mr. J. Fannon,		
	Address 58 St. Bridgets Road, Clondalkin, Co. Dublin		
5. APPLICANT	Name Clondalkin Community Council,		
	Address		
6. DECISION	O.C.M. No.	PA/414/80	Notified 6th March, 1980
	Date	5th March, 1980	Effect To grant permission
7. GRANT	O.C.M. No.	PBD/223/80	Notified 17th April 1980
	Date	17th April 1980	Effect Permission granted
8. APPEAL	Notified		Decision
	Type		Effect
9. APPLICATION SECTION 26 (3)	Date of application		Decision
			Effect
10. COMPENSATION	Ref. in Compensation Register		
11. ENFORCEMENT	Ref. in Enforcement Register		
12. PURCHASE NOTICE			
13. REVOCATION or AMENDMENT			
14.			
15.			
16.			
Prepared by		Copy issued by	
Checked by		Date	
Grid Ref.	O.S. Sheet	Co. Accts. Receipt No.	

# DUBLIN COUNTY COUNCIL<sup>P8 D/ 2.2.3. / 8.0.</sup>

Tel. 724755(Ext. 262/264)

PLANNING DEPARTMENT  
DUBLIN COUNTY COUNCIL  
IRISH LIFE CENTRE  
LOWER ABBEY STREET  
DUBLIN 1

Notification of Grant of Permission/Approval  
~~XXXXXX~~  
Local Government (Planning and Development) Acts, 1963 & 1976

To: Kay Doyle,  
Clondalkin Community Council,  
c/o 66 St. Brigid's Road,  
Clondalkin, Co. Dublin,  
Applicant Kay Doyle (Clondalkin Community Council),

Decision Order  
Number and Date PA/A15/80: 5/3/80  
Register Reference No. T.A. 86  
Planning Control No. 13177  
Application Received on 21/1/80

A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.

Proposed erection of Oil Tank at Swimming Pool at Mangar Road, Clondalkin, Co. Dublin,

CONDITIONS	REASONS FOR CONDITIONS
<p>1. Subject to the conditions of this permission that the development be carried out and completed strictly in accordance with the plans and specification lodged with the application.</p> <p>2. That before development commences approval under the Building Bye-Laws be obtained and all conditions of that approval be observed in the development.</p> <p>3. That the requirements of the Chief Fire Officer be ascertained and strictly adhered to in the development.</p> <p>4. That the proposed tank be painted grey in colour to match finish of building.</p> <p>5. That the requirements of the Parks Superintendent be ascertained and adhered to in this development.</p> <p>6. That sufficient capacity be provided in spillage area to contain entire volume of oil tank in the event of leakage.</p>	<p>1. To ensure that the development shall be in accordance with the permission and that effective control be maintained.</p> <p>2. In order to comply with the Sanitary Services Acts, 1878 - 1964.</p> <p>3. In the interest of safety and the avoidance of fire hazard.</p> <p>4. In the interest of visual amenity.</p> <p>5. In the interest of the proper planning and development of the area.</p> <p>6. To comply with the provisions of the Water Pollution Act, 1977.</p>

Signed on behalf of the Dublin County Council:.....

for Principal Officer

Date: 17 APR 1980

Approval of the Council under Building Bye-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.

FUTURE PRINT