

COMHAIRLE CHONTAE ÁTHA CLIATH

File Reference	LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACT 1963 & 1976 PLANNING REGISTER	REGISTER REFERENCE SA.1616
1. LOCATION	J. F. Kennedy Ind. Est., Bluebell, Dublin 12. S	
2. PROPOSAL	Conversion,	
3. TYPE & DATE OF APPLICATION	TYPE	Date Received
	P	20th Sept. 1979
		Date Further Particulars
		(a) Requested
		(b) Received
		1. 16th Nov. 1979
		2. _____
4. SUBMITTED BY	Name P. N. Shaffrey, & Partners.	
	Address 18 Dartmouth Sq., North, Leeson Park, Dublin 6.	
5. APPLICANT	Name Power Meats Ltd.,	
	Address Gtesham House, Marine Road, Dun Laoghaire,	
6. DECISION	O.C.M. No.	Notified
	Date	Effect
7. GRANT	O.C.M. No.	Notified
	Date	Effect
8. APPEAL	Notified	Decision
	Type	Effect
9. APPLICATION SECTION 26 (3)	Date of application	Decision
		Effect
10. COMPENSATION	Ref. in Compensation Register	
11. ENFORCEMENT	Ref. in Enforcement Register	
12. PURCHASE NOTICE		
13. REVOCATION or AMENDMENT		
14.		
15.		
16.		

Prepared by	Copy issued by.....Registrar.
Checked by	Date.....
Grid Ref.	O.S. Sheet
	Co. Accts. Receipt No.....

S.A. 1616

Philip M. Shaffrey & Partners,
18 Dartmouth Square North,
Leeson Park,
Dublin 6.

16th November, 1979.

re/ Proposed conversion (change of use) of John F. Kennedy
Industrial Estate, Bluebell, for Power Masts Limited.

A Chara,

With reference to your planning application received here on 20th September, 1979 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning and Development) Acts, 1963 and 1976 the following additional information must be submitted in quadruplicate :-

1. Clarification is required as to whether or not off-street car parking in accordance with the requirements of the Development Plan can be provided.

These are as follows :

- (a) Manufacturing - five car spaces per 1,000 sq.ft. gross floor area.
- (b) Warehousing - one car space per 1,000 sq.ft. gross floor area.
- (c) Offices - four car space per 1,000 sq.ft. gross floor area.

2. Clarification is required as to whether or not any killing operations will be carried out at the site.

3. Details of ventilation are required : this should provide for equipment to ensure that meat in cutting, packing and assembly does not reach an internal temperature in excess of +7°C. Information on steam extraction required. Details of facilities for storage of waste material required. Walls of food rooms should be finished with light coloured washable coating or paint to height of at least 2m. with rounded angles and corners. Details of canteen facilities to be submitted.

N.B. The applicant should mark his reply "Additional Information" and quote the Reg. Ref. No. given above.

Yours in meas,



for Principal Officer.