

DUBLIN COUNTY COUNCIL

PLANNING DEPARTMENT,
46 - 49 DAME STREET,
DUBLIN 2.

Tel. 742951 (Ext. 143/145)

~~XXXXXXXX~~
Notification of Grant of Permission/Approval
Local Government (Planning and Development) Acts, 1963 & 1976

To: Messrs. Donal W. Bergin & Associates,
Consulting Engineers,
19, Terenure Road, West,
Dublin, 6.
Clonsilla Paper Mills.

Decision Order
Number and Date PA/39.13/79: 16/11/79
Register Reference No. S.A. 652
Planning Control No. 12137
24.4.79
Application Received on 25/10/79

Applicant
A PERMISSION/APPROVAL has been granted for the development described below subject to the undermentioned conditions.
proposed foul sewer line at Council Sewer, Clonsilla, Co. Dublin.

CONDITIONS

1. Subject to the conditions of this permission that the development be carried out and completed strictly in accordance with the plans and specifications lodged with the application.
2. The applicant to consult with the Roads Engineer regarding safety measures to be taken during the laying of the sewer across the very heavily trafficked Ninth Lock Road.
3. The applicant to consult with the various bodies concerned regarding the exact cover for all the existing services on Ninth Lock Road.
4. Pending completion of the Grand Canal Sewer and the duplication of the Ninth Lock sewer the spare capacity in the existing foul sewer serving the area is restricted. Until the above schemes are completed, only a limited flow can be accepted from the applicant who should consult with the Design Section of the Sanitary Services Department concerning the flow that can be accepted in the interim during which time the discharge into the Council's main shall be controlled by means of a sluice valve placed on the applicant's own expense. *the applicant's sewer near the outfall at*
The Council's maintenance staff will have control over the operation of this valve.

REASONS FOR CONDITIONS

1. To ensure that the development shall be in accordance with the permission, and that effective control be maintained.
2. In the interest of public safety.
3. In the interest of amenity.
4. In order to comply with the Sanitary Authority.

Contd. ...

Signed on behalf of the Dublin County Council:

P.K.
for Principal Officer

Date: 1 FEB 1980

Approval of the Council under Building Bye-Laws must be obtained before the development is commenced and the terms of approval must be complied with in the carrying out of the work.

4. (Contd.) The sewage discharged into the Council's sewer shall be subject to the provisions of the Water Pollution Act, and at no time shall its B.O.D. exceed 400 parts per/million or the total solids therein exceed 400 parts per/million.
5. That the sewer be laid via Manhole 7 to Manhole 10, 11 rather than along the Ninth Lock Road.
6. The crossing of the new Hangor Road to be carried out in accordance with the requirements of the Roads Engineer.
5. In order to comply with the Sanitary Authority.
6. To ensure a satisfactory standard of development.

P.K.

For Principal Officer.