


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)		Plan Register No. S99B/0593
1. Location	Glassamucky, Bohernabreena, Tallaght, Dublin 24.		
2. Development	Bio-cycle treatment plant, percolation area and associate work.		
3. Date of Application	06/09/99	Date Further Particulars (a) Requested (b) Received	
3a. Type of Application	Permission	1. 04/11/1999 2.	1. 2.
4. Submitted by	Name: Jim Hoey, Address: Glassamucky, Bohernabreena,		
5. Applicant	Name: Jim Hoey, Address: Glassamucky, Bohernabreena, Tallaght, Dublin 24.		
6. Decision	O.C.M. No. 2429 Date 04/11/1999	Effect FI REQUEST ADDITIONAL INFORMATION	
7. Grant	O.C.M. No. Date	Effect FI REQUEST ADDITIONAL INFORMATION	
8. Appeal Lodged			
9. Appeal Decision			
10. Material Contravention			
11. Enforcement	Compensation	Purchase Notice	
12. Revocation or Amendment			
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal	
14. Registrar	Date	Receipt No.	

SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



PLANNING  
DEPARTMENT  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 2429	Date of Decision 04/11/1999
Register Reference S99B/0593	Date: 06/09/99

Applicant Jim Hoey,  
Development Bio-cycle treatment plant, percolation area and associate work.

Location Glassamucky, Bohernabreena, Tallaght, Dublin 24.

App. Type Permission


Dear Sir/Madam,

With reference to your planning application, received on 06/09/99 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning & Development) Acts 1963-1993, the following **ADDITIONAL INFORMATION** must be submitted in quadruplicate:

- 1 The applicant is requested to submit the package treatment plant design, certified by the supplier and to include details of the preferred unit size and numbers to be catered for.
- 2 The applicant is requested to submit percolation test results and percolation design, certified by a qualified engineer in accordance with agreement certificate 96/0033. Information should include water table level. The irrigation design should meet certification requirements and the design to be submitted.
- 3 The applicant is requested to submit a site layout map indicating the location of the existing soakage/percolation area from the septic tank.
- 4 The applicant is requested to submit existing watermain layout including connection to the public watermain.

Jim Hoey,  
Glassamucky,  
Bohernabreena,  
Tallaght,  
Dublin 24.

SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS



PLANNING  
DEPARTMENT  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104

REG REF. S99B/0593

5 The applicant is requested to submit details of a trial hole  
being opened for inspection in the vicinity of the  
percolation area.

Signed on behalf of South Dublin County Council

*WP*  
.....  
for Senior Administrative Officer

04/11/99