

	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)	Plan Register No. S99B/0564
1. Location	21 The Rise, Boden Park, Rathfarnham, Dublin 14.	
2. Development	Single storey extension to side and rear.	
3. Date of Application	25/08/99	Date Further Particulars (a) Requested (b) Received
3a. Type of Application	Permission	1. 20/10/1999 1. 2. 2.
4. Submitted by	Name: Kevin O'Halloran, Address: 21 The Rise, Boden Park,	
5. Applicant	Name: Kevin O'Halloran, Address: 21 The Rise, Boden Park, Rathfarnham, Dublin 14.	
6. Decision	O.C.M. No. 2284 Date 20/10/1999	Effect FI REQUEST ADDITIONAL INFORMATION
7. Grant	O.C.M. No. Date	Effect FI REQUEST ADDITIONAL INFORMATION
8. Appeal Lodged		
9. Appeal Decision		
10. Material Contravention		
11. Enforcement	Compensation	Purchase Notice
12. Revocation or Amendment		
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal
14. Registrar	Date	Receipt No.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 2284	Date of Decision 20/10/1999
Register Reference S99B/0564	Date: 25/08/99

Applicant Kevin O'Halloran,
Development Single storey extension to side and rear.
Location 21 The Rise, Boden Park, Rathfarnham, Dublin 14.
App. Type Permission

Dear Sir/Madam,

With reference to your planning application, received on 25/08/99 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning & Development) Acts 1963-1993, the following ADDITIONAL INFORMATION must be submitted in quadruplicate:

- 1 There is a 225mm diameter foul sewer adjacent to the proposed extension. The applicant is requested to determine and indicate on plans the exact location of this sewer. The design of the proposed extension may need to be revised to ensure that no part of the extension is within 5m of the sewer. The applicant is requested to submit revised plans as necessary.
- 2 The applicant is requested to submit details of the proposed drainage indicating complete separation of the foul and surface water systems.
- 3 The applicant is requested to submit revised plans showing the rear elevation titled as such.

Signed on behalf of South Dublin County Council

LN
.....
for Senior Administrative Officer

21/10/99

Kevin O'Halloran,
21 The Rise,
Boden Park,
Rathfarnham,
Dublin 14.