


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)		Plan Register No. S99B/0277	
1. Location	14 St. Aongus Crescent, Tymon North, Tallaght, Dublin 24.			
2. Development	Two storey extension to side and single storey extension to front.			
3. Date of Application	28/04/99	Date Further Particulars (a) Requested (b) Received		
3a. Type of Application	Permission	1.	1.	
		2.	2.	
4. Submitted by	Name: Robert Hogan,			
	Address: 16 St, Aongus Crescent, Tymon North,			
5. Applicant	Name: Mr. & Mrs. P. Keating,			
	Address: 14 St. Aongus Crescent, Tymon North, Tallaght, Dublin 24.			
6. Decision	O.C.M. No. 1299	Effect		
	Date 22/06/1999	RP REFUSE PERMISSION		
7. Grant	O.C.M. No.	Effect		
	Date	RP REFUSE PERMISSION		
8. Appeal Lodged				
9. Appeal Decision				
10. Material Contravention				
11. Enforcement	Compensation	Purchase Notice		
12. Revocation or Amendment				
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal		
14. Registrar	Date	Receipt No.		

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

NOTIFICATION OF DECISION TO REFUSE PERMISSION
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 1299	Date of Decision 22/06/1999
Register Reference S99B/0277	Date 28/04/99

Applicant Mr. & Mrs. P. Keating,
Development Two storey extension to side and single storey extension to front.
Location 14 St. Aongus Crescent, Tymon North, Tallaght, Dublin 24.

Floor Area Sq Metres

Time extension(s) up to and including

Additional Information Requested/Received /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a decision to REFUSE PERMISSION in respect of the above proposal.

for the (1) Reasons on the attached Numbered Pages.

Signed on behalf of the South Dublin County Council

.....
for SENIOR ADMINISTRATIVE OFFICER 22/06/99

Robert Hogan,
16 St, Aongus Crescent,
Tymon North,
Tallaght,
Dublin 24.

SOUTH DUBLIN COUNTY COUNCIL
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS

Bosca 4122,
Lár an Bhaile, Tamhlacht,
Baile Átha Cliath 24.

Telefon: 01-414 9000
Facs: 01-414 9104



PLANNING
DEPARTMENT
P.O. Box 4122,
Town Centre, Tallaght,
Dublin 24.

Telephone: 01-414 9000
Fax: 01-414 9104

REG REF. S99B/0277

Reasons

- 1 The proposed extension would come within 5 metres of an existing 225mm diameter surface water sewer at an average depth of 2.325 metres which is not acceptable due to the mutual risk of damage to the sewer and to the proposed extension, inadequate room for maintenance/repair of the sewer and the risk to public health.