


	South Dublin County Council Local Government (Planning & Development) Acts 1963 to 1993 Planning Register (Part 1)		Plan Register No.  S99B/0133	
1. Location	17 Whitebrook Park, Tallaght, Dublin 24.			
2. Development	Two storey extension to side, extended front vehicular gate entrance.			
3. Date of Application	02/03/99	Date Further Particulars (a) Requested (b) Received		
3a. Type of Application	Permission	1. 29/04/1999	1. 04/11/1999	
		2.	2.	
4. Submitted by	Name: Eamon Weber Architect, Address: 26 Aranleigh Mount, Rathfarnham,			
5. Applicant	Name: F. Conlon, Address: 17 Whitebrook Park, Tallaght, Dublin 24.			
6. Decision	O.C.M. No. 2826	Effect		
	Date 20/12/1999	RP REFUSE PERMISSION		
7. Grant	O.C.M. No.	Effect		
	Date	RP REFUSE PERMISSION		
8. Appeal Lodged				
9. Appeal Decision				
10. Material Contravention				
11. Enforcement	Compensation	Purchase Notice		
12. Revocation or Amendment				
13. E.I.S. Requested	E.I.S. Received	E.I.S. Appeal		
14. .... Registrar	..... Date	..... Receipt No.		

**SOUTH DUBLIN COUNTY COUNCIL  
COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

**NOTIFICATION OF DECISION TO REFUSE PERMISSION  
LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993**

Decision Order Number 2826	Date of Decision 20/12/1999
Register Reference S99B/0133	Date 02/03/99

**Applicant** F. Conlon,  
**Development** Two storey extension to side, extended front vehicular gate entrance.  
**Location** 17 Whitebrook Park, Tallaght, Dublin 24.

**Floor Area** Sq Metres

**Time extension(s)** up to and including

**Additional Information Requested/Received** 29/04/1999 /04/11/1999

**Clarification of Additional Information Requested/Received** /

In pursuance of its functions under the above mentioned Acts, the South Dublin County Council, being the Planning Authority for the County Health District of Dublin, did by Order dated as above make a decision to REFUSE PERMISSION in respect of the above proposal.

for the (1) Reason on the attached Numbered Pages.

Signed on behalf of the South Dublin County Council

.....  
for SENIOR ADMINISTRATIVE OFFICER


20/12/99

Eamon Weber Architect,  
26 Aranleigh Mount,  
Rathfarnham,  
Dublin 14.

**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

REG REF. S99B/0133

**Reasons**

- 1 The Planning Authority note that there is an existing 100mm diameter watermain located approximately 3.86 metres from the proposed extension. The applicant has not demonstrated that the proposed development meets the requirements of the Planning Authority in respect of distance of the proposed development from existing services. The proposed development would be prejudicial to public health and contrary to the proper planning and development of the area.

**SOUTH DUBLIN COUNTY COUNCIL**  
**COMHAIRLE CHONTAE ÁTHA CLIATH THEAS**

Bosca 4122,  
Lár an Bhaile, Tamhlacht,  
Baile Átha Cliath 24.

Telefon: 01-414 9000  
Facs: 01-414 9104



**PLANNING  
DEPARTMENT**  
P.O. Box 4122,  
Town Centre, Tallaght,  
Dublin 24.

Telephone: 01-414 9000  
Fax: 01-414 9104

LOCAL GOVERNMENT (PLANNING AND DEVELOPMENT) ACTS, 1963 TO 1993

Decision Order Number 0898	Date of Decision 29/04/1999
Register Reference S99B/0133	Date: 02/03/1999

**Applicant** F. Conlon,  
**Development** Two storey extension to side, extended front vehicular gate entrance.

**Location** 17 Whitebrook Park, Tallaght, Dublin 24.

**App. Type** Permission

Dear Sir/Madam,

With reference to your planning application, received on 02/03/1999 in connection with the above, I wish to inform you that before the application can be considered under the Local Government (Planning & Development) Acts 1963-1993, the following **ADDITIONAL INFORMATION** must be submitted in quadruplicate:

- 1 The applicant is requested to submit revised plans showing the exact position of a 150mm diameter watermain indicated in Council records as being in the verge of Whitebrook Park i.e. along the west boundary of the property. No building is to be within 5 metres of a 150mm diameter watermain.

Signed on behalf of South Dublin County Council

.....  
for Senior Administrative Officer

29/04/1999

Eamon Weber Architect,  
26 Aranleigh Mount,  
Rathfarnham,  
Dublin 14.