

Register Reference: SD21A/0044

Development: Construction of a new two storey clubhouse (658sq.m); new external activity area (405sq.m); new boundary fencing for external activity area and all associated site works adjacent to existing all weather pitch.

Location: Treepark Road, Kilnamanagh, Dublin 24

Applicant: Kilnamanagh AFC

Application Type: Permission

Planning Officer:

Development Summary:

The above proposal **is acceptable** to the Environmental Health Department – subject to the following conditions:

Construction Phases:

Noise

No Equipment or Machinery (to include pneumatic drills, construction vehicles, generators, etc.) shall be operated on or adjacent to the site before 7.00 hours on weekdays and 9.00 hours on Saturdays nor after 19.00 hours on weekdays and 13.00 hours on Saturdays, nor at any time on Sundays, Bank Holidays or Public Holidays. Any work outside these hours shall only be permitted following receipt of the written consent of the Planning Authority, having regard to the reasonable justification and No Equipment or Machinery (to include pneumatic drills, construction circumstances and a commitment to minimise as far as practicable any unwanted noise outside the hours stated above.

Reason: In the interest of public health by the prevention of unacceptable levels of noise pollution which could interfere with normal sleep and rest patterns and/or when people could reasonably expect a level of quietness.

Plant equipment with low inherent potential for generation of noise shall be selected and used. Generators and high duty compressors shall be provided with localised barriers or acoustic barriers as appropriate.

Reason: In the interest of public health.

Air Quality

During the construction phase of the development, Best Practicable Means shall be employed to minimise air blown dust being emitted from the site. This shall include covering skips and slack-heaps, netting of scaffolding, daily washing down of pavements or other public areas, and any other precautions necessary to prevent dust nuisances.

Reason: To contain dust arising from construction / demolition in the interests of public health and to prevent nuisance being caused to occupiers of buildings in the vicinity.



Thomas Mangan
Environmental Health Officer
22nd March 2021

Gillian Wynne
Senior Environmental Health Officer
22nd March 2021