

Water Services Planning Report

Register Reference No.: SD21A/0101

Development: Residential development comprising a total of 28 apartments, in a building up to 4-storeys in height; the cumulative gross floor area is proposed to be 2,640sq.m on the 0.3157 hectare site including the site of the former filling station (0.2821 ha - under applicant's ownership) and a portion of land (0.0326ha) located to the north of the filling station site, where the existing traffic lights and pedestrian crossing are located along Nutgrove Avenue; to accommodate access to the site, it is proposed to relocate the existing traffic lights and pedestrian crossing which traverses both South Dublin County Council and Dun Laoghaire-Rathdown County Council boundaries; a development with a maximum height of c.11.7m and a total gross floor area of 2,640 sq.m comprising of 28 residential units comprising 8 1-bedroom apartments, 17 2-bedroom apartments and 3 3-bedroom apartments; communal amenity space (433sq.m) and public open space (286sq.m) located to the rear and western side of the site; at grade car parking is proposed to the rear of the site which will provide 16 residents' car parking spaces (including 2 electric vehicles spaces and 1 accessible spaces) and 2 motorcycle parking spaces; 2 resident waste bin storage areas are proposed along the north-western and north-eastern corner of the site, fronting Nutgrove Avenue (total 25sq.m); a new vehicular entrance from Nutgrove Avenue; a total of 62 surface level bicycle parking spaces comprising 48 spaces located at the rear of the site and 14 spaces within the residents' communal area, located along the north-western portion of the site; relocation of the existing traffic lights and pedestrian crossing located on Nutgrove Avenue to the west of its existing position to accommodate access to the site; all ancillary site development works including installation of drainage and water supply infrastructure, lighting and provision of an ESB substation and switch room.

Location: Nutgrove Avenue, Rathfarnham, Dublin 14

Report Date: 28th May 2021

Surface Water Report:

No objection subject to:

1.1 Prior to commencement of development the applicant is required to submit a drawing in plan and cross-sectional view showing the location of a petrol interceptor where surface water run off is drained from car parking areas. Any proposed petrol/oil interceptor shall be in advance of attenuation system.

Water Services Planning Report

Flood Risk

No Objection

All floor levels shall be a minimum of 500mm above the highest know flood level for the site where same occurs.

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
 Brian Harkin SEE.

Date: _____

Endorsed: _____
 Chris Galvin SE.

Date: _____