

**Irish Water's Statutory
Response to**

South Dublin

Planning Authority



Uisce Éireann
Bosca OP 6000
Baile Átha Cliath 1
Éire

Irish Water
PO Box 6000
Dublin 1
Ireland

T: +353 1 89 25000
F: +353 1 89 25001
www.water.ie

Planning Application No.

SD21B/0296

Date Lodged with Planning Authority:

20/05/2021

Development:

Refurbishment works to existing dwelling involving: (a) demolition of a single storey structure, existing windows, roof and gable wall, part of the existing dwelling; (b) removal of two existing rooflights; (c) alteration to the existing main entrance door (d) new dormer window in the existing roof to the rear elevation; (e) new roof light in the existing roof to the front elevation; (f) construction of a new 2 storey extension with new windows to the front and rear elevations; (g) associated internal works and drainage; (h) associated external works; (i) and permission for retention of existing shed structure on the site.

Location :

2, Ballyroan Lodge, Dublin 16

IW Recommendation:**Further Information Required****IW Observations:****1 Water**

1.1 All works are to comply with the Irish Water Standard Details & Code of Practice for Water Infrastructure

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul

2.1 The applicant has shown the surface water run off from the proposed development to be connected into the foul water drainage network. This is not acceptable as foul and surface water drainage systems must be designed to discharge to separate pipe networks. The applicant is required to submit a revised surface and foul water drainage layout drawing for the proposed development clearly showing that the foul and surface water drainage systems are discharging to separate pipe networks.

If separation of surface water and foul water drainage systems is not feasible on the site and all alternatives have been considered, such as infiltration soakaway systems,, then the applicant is required to submit a Letter of agreement from Irish Water to the planning authority which clearly states that Irish Water are in agreement with the applicant's proposal to connect surface water drainage from the proposed development into the existing foul water drainage network.

Reason: In the interest of public health and to ensure adequate wastewater facilities.

Signed on Behalf of Irish Water:

Maria O'Dwyer

Date:

Thursday 24 June 2021