

**Irish Water's Statutory  
Response to**

**South Dublin**

**Planning Authority**



**Uisce Éireann**  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

**Irish Water**  
PO Box 6000  
Dublin 1  
Ireland

**T: +353 1 89 25000**  
**F: +353 1 89 25001**  
**[www.water.ie](http://www.water.ie)**

**Planning Application No.**

SD21A/0129

**Date Lodged with Planning Authority:**

24/05/2021

**Development:**

Two storey extension (floor area 199sq.m) containing 1 classroom at ground floor level; 1 classroom and an assisted shower room at first floor level to the rear of existing two storey school building (floor area 2,767sq.m); new roof window to existing roof surface of adjacent stairwell, together with all associated site works.

**Location :**

Gaelscoil Naomh Pdraig, Castle Road, Lucan, Co. Dublin

**IW Recommendation:****Further Information Required****IW Observations:****1 Water**

- Submit a pre connection enquiry with Irish Water regarding proposed development. Obtain a letter of Confirmation of Feasibility of proposed development from Irish water and submit same to Planning Authority.

Reason: In the interest of public health and to ensure adequate water facilities.

**2 Foul**

- Submit a pre connection enquiry with Irish Water regarding proposed development especially with regard to diverting existing 600mm diameter foul sewer. Obtain a letter of Confirmation of Feasibility of proposed development from Irish water and submit same to Planning Authority.

Reason: In the interest of public health and to ensure adequate waste water facilities.

Signed on Behalf of Irish Water:

Maria O'Dwyer

Date:

Tuesday 29 June 2021