

An Rannóg Talamhúsáide, Pleanála agus Iompair  
Land Use, Planning & Transportation Department  
Telephone: 01 4149000 Fax: 01 4149104 Email: [planning.dept@sdublincoco.ie](mailto:planning.dept@sdublincoco.ie)

Shona D'Arcy & Brian Hutchinson  
2, Ballyroan Lodge  
Dublin 16

**PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING  
REGULATIONS THEREUNDER**

<b>Decision Order Number:</b> 0950	<b>Date of Decision:</b> 13-Jul-2021
<b>Register Reference:</b> SD21B/0296	<b>Registration Date:</b> 20-May-2021

**Applicant:** Shona D'Arcy & Brian Hutchinson

**Development:** Refurbishment works to existing dwelling involving: (a) demolition of a single storey structure, existing windows, roof and gable wall, part of the existing dwelling; (b) removal of two existing rooflights; (c) alteration to the existing main entrance door (d) new dormer window in the existing roof to the rear elevation; (e) new roof light in the existing roof to the front elevation; (f) construction of a new 2 storey extension with new windows to the front and rear elevations; (g) associated internal works and drainage; (h) associated external works; (i) and permission for retention of existing shed structure on the site.

**Location:** 2, Ballyroan Lodge, Dublin 16

**Application Type:** Permission and Retention

Dear Sir /Madam,

With reference to your planning application, received on 20-May-2021 in connection with the above, I wish to inform you that before the application can be considered under Section 33 of the Planning & Development Act 2000, six copies of the following ADDITIONAL INFORMATION must be submitted.

1. (1) The applicant has shown the surface water run off from the proposed development to be connected into the foul water drainage network. This is not acceptable as foul and surface water drainage systems must be designed to discharge to separate pipe networks. The applicant is requested to submit a revised surface and foul water drainage layout drawing for the proposed development clearly showing that the foul and surface water drainage systems are discharging to separate pipe networks and to investigate the potential to incorporate a soakaway on site to separate the surface and foul water drainage systems. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for a proposed soakaway in accordance with BRE

Digest 365 – Soakaway Design.

(2) The applicant is requested to submit a revised drawing showing plan & cross-sectional views, dimensions, and location of a proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:

(i) At least 5m from any building, public sewer, road boundary or structure.

(ii) Generally, not within 3m of the boundary of the adjoining property.

(iii) Not in such a position that the ground below foundations is likely to be adversely affected.

(iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.

(3) The applicant is requested to submit details of water butts as part of SuDS (Sustainable drainage systems) measures for the proposed development.

2. Given the proximity of the site and proposed extension to the Owendoher River the applicant is requested to submit a drawing showing the location of the proposed development site in relation to adjacent flood zones identified within OPW's (Office of Public Works) CFRAM maps. The applicant is requested to outline details of the measures and design features to prevent/mitigate the risk of flooding to the proposed development and to adjoining lands. Finished floor levels should be above the closest known 1 in 100 year river flood level data point with appropriate freeboard.

**NOTE:** The applicant should note that any submission made in response to the above will be examined and MAY be deemed to be SIGNIFICANT ADDITIONAL INFORMATION by the Planning Authority. In this event the applicant(s) will be subsequently notified and requested to publish a notice in an approved newspaper and erect or fix a site notice on the land or structure to which the further information relates and to submit copies of the both the newspaper and site notices to the Planning Authority in accordance with Article 35 (1) (a) and (b) of the Planning and Development Regulations 2001 (as amended).

**Note:** The applicant must submit the Further Information within **6 months** of the **date of decision**. If the information is not received within this period the planning authority shall declare the application to be withdrawn.

**Please ensure that your reply to this Request for Additional Information is accompanied by a covering letter marked "ADDITIONAL INFORMATION" and that the Planning Register Reference Number given above is quoted on the covering letter.**

Signed on behalf of South Dublin County Council

**Register Reference:** SD21B/0296

**Date:** 13-Jul-2021

Yours faithfully,

  
for **Senior Planner**