Water Services Planning Report

Register Reference No.:	SD21B/0286
Development:	Extension to side of existing house.
Location:	194, Arthur Griffith Park, Lucan, Co. Dublin
Application Type:	Permission
Report Date:	22 nd June 2021

Surface Water Report:

Further information Required:

- 1.1 The applicant has proposed to discharge surface water run off from the proposed development to the foul water drainage network. The applicant is required to investigate the potential to incorporate a soakaway on site to separate the surface and foul water drainage systems. The applicant is required to submit a report showing site specific soil percolation test results and design calculations for a proposed soakaway in accordance with BRE Digest 365 Soakaway Design.
- **1.2** The applicant is required to submit a revised drawing showing plan & crosssectional views, dimensions, and location of a proposed soakaway. Any proposed soakaway shall be located fully within the curtilage of the property and shall be:
- i) At least 5m from any building, public sewer, road boundary or structure.
- ii) Generally, not within 3m of the boundary of the adjoining property.
- iii) Not in such a position that the ground below foundations is likely to be adversely affected.
- iv) 10m from any sewage treatment percolation area and from any watercourse / floodplain.
- **1.3** The applicant shall include water butts as part of SuDS (Sustainable drainage systems) measures for the proposed development.
- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
- All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.

Water Services Planning Report

<u>Flood Ris</u>	<u>k Report:</u>		No objection:
Water Report:			Referred to IW
<u>Foul Drain</u>	age Report:		Referred to IW
Signed:	Ronan Toft AE	Date:	
Endorsed:	Brian Harkin SEE	Date:	