

An Rannóg Talamhúsáide, Pleanála agus Iompair
Land Use, Planning & Transportation Department
Telephone: 01 4149000 Fax: 01 4149104 Email: planning.dept@sdublincoco.ie

Vicky Landy,
RKD Architects
59, Northumberland Road
Ballsbridge
Dublin 4

Date: 27-Jul-2021

PLANNING & DEVELOPMENT ACT, 2000 (as amended) AND PLANNING REGULATIONS THEREUNDER

Register Reference: SD21A/0203

Development: Modifications and minor additions to previously approved scheme (Planning Register Reference SD20A/0283) at this site of c.16.23 Ha (in total) comprising of the following changes to previously approved scheme SD20A/0283; Approved Central Administration Building (CAB), relocation of building to the east by approx. 7m; reconfiguration and setting out of building plans at all levels (including roof level) resulting in increase in building footprint of approximately 170sq.m (from 1,424sq.m to 1,594sq.m) associated changes to building elevations (design and finishes); approved single storey Cafeteria Element, additional basement level below cafeteria to accommodate plant; 9 rooflights (2.8 m diameter) and 9 rooflight (1.8m diameter), inclusion of MEP Plant on roof level including new flue extending approx. 1m above parapet; approved four-storey Office element, parapet at roof level to be raised by approx. 1.1m (increased from approved 19.5m in height to proposed 20.6m); overall increase in GIFA of 395sq.m; reconfiguration of area available for PV panels and sedum roof finish in order to accommodate required MEP equipment at roof levels. approved Data Centres - DUB14 and DUB15, reconfiguration and setting out affecting building locations and plans at all levels (including roof level) resulting in reduction in overall building footprint (for each building) by 48sq.m (from 13,442sq.m to 13,394sq.m), associated changes to staircases design, building elevations design and finishes, increase in parapet height of Vent Houses (at roof level) by approx. 350mm and omission of previously proposed zone of sedum roof finish; overall decrease in GIFA of 1,352sq.m in respect of DUB 14 and decrease of 1,453sq.m in respect of DUB 15; all plant equipment at ground level - reduced in height compared to approved layout so that the screening is deemed not required; DUB 14, reduction in height of approved flues by approx. 650mm, reduction in number of flues from 11 approved to 8 proposed; DUB 15, change to level of ground floor and associated increase in overall building height of approx. 700mm (parapet height increased from approved +83.0m O.D. to proposed +83.7m O.D.); reconfiguration of associated external plant at ground level (including generators / E-Houses & transformers) flues, omission of approved Modular Electrical Rooms (MERs) and associated screening serving approved Data Centres DUB14 & 15; relocation, modifications to design and expansion of approved Water Treatment Building and associated plant to include, Water Treatment Tanks, 2 sprinkler tanks and relocated approved pump house (contained in the main Water

An Rannóg Talamhúsáide, Pleanála agus Iompair
Land Use, Planning & Transportation Department
Telephone: 01 4149000 Fax: 01 4149104 Email: planning.dept@sdublincoco.ie



documentation with a planning application which you/your client may not wish to have publicly available.

Yours faithfully,

 Z. McAuley
for Senior Planner