Irish Water's Statutory Response to	South Dublin	Planning Authority
Planning Application No.		SD21B/0347

UISCE EIREANN : IRISH WATER

Uisce Éireann Bosca OP 6000 Baile Átha Cliath 1

Irish Water PO Box 6000 Dublin 1 Ireland

T: +353 1 89 25000 F: +353 1 89 25001 www.water.ie

Development:

Date Lodged with Planning Authority:

First floor rear extension; two storey side extension; removal of main existing pitched roof on dwelling and replacement of same with a mixture of pitch and flat roof; 1 'Velux' window in front and rear of new roof; 3 'Velux' windows in side north face of new roof; 1 dormer structure with 3 obscure windows on side south face of new roof; all associated site works.

15/06/2021

Location:

432A, Orwell Park Green, Dublin 6W



IW Recommendation: Further Information Required

IW Observations:

- 1 Water (Further Information Required)
- 1.1The proposed development is approximately 1.9m from a 4" uPVC public watermain located under the public footpath to the north of the site. Irish Water Standard Details for water Infrastructure require 3m clear distance from a main of this size. The applicant shall engage with Irish Water's diversions section to assess feasibility of existing design and an alternative design which accommodates Irish Water's minimum required separation distances from public infrastructure. The outcome of this engagement with Irish Water's diversions shall be submitted to the planning authority as a response to Request for Further Information
- 1.2 All works are to comply with the Irish Water Standard Details & Code of Practice for Water Infrastructure

Reason: In the interest of public health and to ensure adequate water facilities.

2 Foul

2.1 All works are to comply with the Irish Water Standard Details & Code of Practice for WasteWater Infrastructure

Reason: In the interest of public health and to ensure adequate wastewater facilities.

Signed on Behalf of Irish Water: Yvonne Harris

Date: Sunday 25 July 2021

