

**Irish Water's Statutory  
Response to**

**South Dublin**

**Planning Authority**



**Uisce Éireann**  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

**Irish Water**  
PO Box 6000  
Dublin 1  
Ireland

**T: +353 1 89 25000**  
**F: +353 1 89 25001**  
**[www.water.ie](http://www.water.ie)**

**Planning Application No.**

SD21A/0181

**Date Lodged with Planning Authority:**

01/07/2021

**Development:**

Alterations to previous approved planning application, Reg. Ref. SD15A/0105, consisting of: construction of a new single storey flat roof modular changing facilities (293sq.m) ancillary to the existing playing pitch; relocation of approved 38 carparking spaces and 2 coach parking bays from northern boundary to the eastern boundary adjacent to Cloverhill Road installation of new overhead flood lights; 3 new flag poles; continuation of previously permitted boundary wall and footpath (Reg. Ref. SD15A/010) extending along the south eastern boundary, with addition of new security fencing added to top of wall, all adjacent to Cloverhill Road; new entrance gates (accessed via the permitted entrance off Cloverhill Road); all associated boundary treatment, landscaping and ancillary works necessary to facilitate the development.

**Location :**

Cloverhill Road, Clondalin, Dublin 22

**IW Recommendation:**

**Further Information Required**

**IW Observations:**

**1 Water**

1.1 In order to assess the if the public water infrastructure has sufficient capacity for the proposed development further information is requested as follows;

The applicant is required to engage with Irish Water through the submission of a Pre-Connection Enquiry (PCE) in order to determine the feasibility of connection to the public water infrastructure. The Confirmation of Feasibility (COF) must be submitted to the planning department as the response to this further information request. Pre-connection enquiries can be made at <https://www.water.ie/connections/get-connected/>.

1.2 The applicant has not submitted water supply drawings for the proposed development.

The applicant is required to submit a drawing in plan outlining the existing and proposed water supply layout for the development. Maps of the public watermains and Wastewater drainage networks may be obtained, if available, for required locations in by emailing: [datarequests@water.ie](mailto:datarequests@water.ie). All proposals are to comply with the Irish Water Standard Details for Water Infrastructure available at (<https://www.water.ie/connections/Water-Standard-Details.pdf>)

1.3 All works are to comply with the Irish Water Standard Details & Code of Practice for Water Infrastructure

Reason: In the interest of public health and to ensure adequate water facilities.

**2 Foul**

2.1 In order to assess the if the public wastewater infrastructure has sufficient capacity for the proposed development further information is requested as follows;

The applicant is required to engage with Irish Water through the submission of a Pre-Connection Enquiry (PCE) in order to determine the feasibility of connection to the public wastewater infrastructure. The Confirmation of Feasibility (COF) must be submitted to the planning department as the response to this further information request. Pre-connection enquiries can be made at <https://www.water.ie/connections/get-connected/>.

2.2 The applicant has not submitted foul water drainage plans for the proposed development.

The applicant is required to submit a drawing showing existing and proposed foul water drainage layouts up to and including the point of connection to the public foul water sewer. The drawing shall include the location of all Aj's, manholes, pipe size, material type and direction of flow. The drawing shall clearly show that the foul and surface water systems are discharging to separate pipe networks. Maps of the public watermains and Wastewater drainage networks may be obtained, if available, for required locations in by emailing: [datarequests@water.ie](mailto:datarequests@water.ie). All works are to comply with Irish Water Standard Details for Wastewater Infrastructure available at (<https://www.water.ie/connections/Wastewater-Standard-Details.pdf>)

Signed on Behalf of Irish Water:

Yvonne Harris

Date:

Friday 6 August 2021

