

**Irish Water's Statutory  
Response to**

**South Dublin**

**Planning Authority**



Uisce Éireann  
Bosca OP 6000  
Baile Átha Cliath 1  
Éire

Irish Water  
PO Box 6000  
Dublin 1  
Ireland

T: +353 1 89 25000  
F: +353 1 89 25001  
[www.water.ie](http://www.water.ie)

**Planning Application No.**

SD21A/0167

**Date Lodged with Planning Authority:**

25.06.21

**Development:**

Construction of a gas fired power plant with an electrical output of up to 125MW with associated balance of plant, equipment and buildings including; an Engine Hall building with a height of 18.9m, comprising 6 gas engines and ancillary infrastructure; an Electrical Annex Building with a height of 18.7m; a Workshop building with a height of 5.1m; a Tank Farm building with a height of 5.68m; a Security hut with a height of 3.27m; an Exhaust Stack with a height of 31.8m; a Gas AGI including a kiosk with height of 3.3m; Radiator Coolers with a height of 8.46m; 2 electrical transformers with a height of 4.98m; Tanks including 2 x Diesel Oil Storage Tanks (volume of 2500m3 combined); SCR Urea Tank (26m3); Lube Oil Storage Tank (26m3); Lube Oil Maintenance Tank (26m3); Pilot Oil Tank (26m3); Fire Water Storage Tank (1000m3); Effluent Collecting Tank (26m3); Underground Surface Water Attenuation Tank (490m3); 2 new access onto the existing private road network with Profile Park; 12 parking spaces, footpaths, landscaping; fencing and all other associated site development plant and equipment and other works including surface water and foul wastewater drainage.

**Location :**

Profile Park, Baldonnel, Dublin 22

**IW Recommendation:**

**No Objection**

**IW Observations:**

Irish Water requests that any grant of permission will be conditioned as follows:

1. The applicant shall sign a connection agreement with Irish Water prior to the commencement of the development and adhere to the standards and conditions set out in that agreement.
2. All development shall be carried out in compliance with Irish Water Standards codes and practices.
3. Any proposals by the applicant to divert or build over existing water or wastewater services shall be submitted to Irish Water for written approval prior to works commencing.
4. Separation distances between the existing Irish Water assets and proposed structures, other services, trees, etc. have to be in accordance with the Irish Water Codes of Practice and Standard Details.

Reason: To ensure adequate provision of water and wastewater facilities.

Signed on Behalf of Irish Water:

Maria O'Dwyer

Date:

Friday 20 August 2021

