

Water Services Planning Report

Register Reference No.: SD21A/0165
Development: Erect a new ball wall to rear including internal alterations to provide new first floor storage with new external escape door and window on south gable; Retention for refreshment kiosk to front and north side elevation.
Location: Glenaulin Park, Palmerstown, Dublin 20
Report Date : 29th July 2021

Surface Water Report:

No objection:

Flood Risk

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Report:

Not Applicable

Foul Drainage Report:

Not Applicable

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____