

Water Services Planning Report

Register Reference No.: SD21A/0175

Development: Revisions to development previously permitted under Reg. Ref. SD17A/0064 and ABP Ref. PL06S.249209 (referred to as Watson's Place) and shall consist of the replacement of 3 previously permitted house units (House Types A, A1 and A2) comprising 1 one bed house, 1 three bed house and 1 four bed house with a new proposal for 8 apartments comprising 2 one bed units and 6 two bed units, all located within 2-3 storey Ballyroan House (A Protected Structure); the replacement of 2 one previously permitted semi-detached house units (House Types D) comprising 2 four bed house units (2 storeys) with a new proposal for 3 two bed terraced house units (2 storeys); the new works to Ballyroan House (A Protected Structure) shall comprise of the refurbishment and subdivision of the existing building (approx. 761sq.m); demolition of extensions to the building including a two storey block work extension and a single storey extension to the rear (total demolition approx. 53sq.m); (c) the removal of an old ruin to the gable; extension to the rear of the building at ground and first floor level (approx. 36sq.m); removal of internal walls and partitions; modifications to elevations including the removal of windows and the provision of new window and door openings; and provision of new private open space terraces/balconies to the rear/side of the building; the revised proposal shall also provide for a total of 43 car parking spaces; public and communal open space areas; 18 secure bicycle parking spaces; new bin storage area (approx. 23sq.m); all other development within the site remains as previously permitted under Reg. Ref. SD17A/0064 and ABP Ref. PL06S.249209

Location: Ballyroan House, Ballyroan Heights, Dublin 16

Report Date : 28th July 2021

Surface Water Report:

No objection subject to:

1.1 Condition 9 of An Bord Pleanala Grant Order no. PL06S.249209 for planning reference SD17A/0064 shall apply

Flood Risk

No Objection:

- The Developer shall ensure that there is complete separation of the foul and surface water drainage for the proposed development.
 - All new precast surface water manholes shall have a minimum thickness surround of 150mm Concrete Class B.
 - All works for this development shall comply with the requirements of the Greater Dublin Regional Code of Practice for Drainage Works.
-

Water Services Planning Report

Water Report:

Referred to IW

Foul Drainage Report:

Referred to IW

Signed: _____
Ronan Toft AE

Date: _____

Endorsed: _____
Chris Galvin SE.

Date: _____